



**WELL DRILLER'S REPORT**

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 7491

1. OWNER George Keosky ADDRESS AT WELL LOCATION \_\_\_\_\_  
MAILING ADDRESS 8200 Janzen Road #12 \_\_\_\_\_  
Modesto, CA 95351 \_\_\_\_\_  
2. LOCATION NW 1/4 NW 1/4 Sec. 9 T. 35 N/S R. 56 E. Elko County  
PERMIT NO. \_\_\_\_\_ Lot 3 Block 58 Meadow Valley #3 Meadow Valley Ranchos  
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK  
New Well  Recondition   
Deepen  Other

4. PROPOSED USE  
Domestic  Irrigation  Test   
Municipal  Industrial  Stock

5. TYPE WELL  
Cable  Rotary   
Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0'	7'	7'
Sand & Gravel w/rocks		7'	15'	8'
Sand & Gravel		15'	20'	5'
Sand & Gravel w/clay		20'	65'	45'
Clay w/some gravel		65'	80'	15'
Gravel w/some clay		80'	105'	25'
Sand (med)		105'	120'	15'
Sand & gravel		120'	188'	68'
First water at 80 feet.				
Installed a 1 1/2" pitless adapter at 4 feet.				
Set a Grundfos SP4-14 1 1/2 H.P. pump at about 174 feet on 1 1/2" galvanized drop pipe.				

8. WELL CONSTRUCTION  
Diameter 10 inches Total depth 188 feet  
\_\_\_\_\_ inches  
\_\_\_\_\_ inches

Casing record  
Weight per foot \_\_\_\_\_ Thickness 156  
Diameter From To  
6-5/8 inches +2 feet 168 feet  
\_\_\_\_\_ inches \_\_\_\_\_ feet \_\_\_\_\_ feet

Surface seal: Yes  No  Type cement  
Depth of seal 46 feet  
Gravel packed: Yes  No   
Gravel packed from 50 feet to 188 feet

Perforations:  
Type perforation Machine slots  
Size perforation 1/8 inch  
From 168 feet to 188 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started June 24, 1987  
Date completed June 26, 1987

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blow Test	25		

BAILER TEST

G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

9. WATER LEVEL  
Static water level 75 feet below land surface  
Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name HACKWORTH DRILLING, INC. Contractor  
Address P.O. Box 850 Contractor  
Nevada contractor's license number issued by the State Contractor's Board 020582  
Nevada contractor's driller's number issued by the Division of Water Resources 1166  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1166  
Signed Dale C. Vidler By driller performing actual drilling on site or Contractor  
Date 6-29-87