WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 28789
Permit No.
Basin 7-92-B Lemmon V. East

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 6813

1. OWNER RICK RUDD
MAILING ADDRESS ~~XXXXXX~~ 11525 Oregon Blvd.
Reno, NV 89506

ADDRESS AT WELL LOCATION Same

2. LOCATION NE ¼ NE ¼ Sec. 15 T. 21N N/S R. 19 E. Washoe County

PERMIT NO. (Issued by Water Resources) | 080-415-02 (Parcel No.) | Lemmon Valley (Subdivision Name)

3. TYPE OF WORK: New Well ☒ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☒ Irrigation ☐ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☐ Rotary ☒ Other ☐ Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	½	½
Green & brown sand		½	9	8½
Boulders		9	12	3
Brown sandy clay		12	111	99
Soft zone		111	118	7
Brown clay		118	181	63
Weathered soft granite		181	186	5
Green granite		186	210	24
Soft small fracture		210	212	2
Green granite		212	222	10
Fracture (NO WATER)		222	226	4
Granite		226	230	4
Soft zone (2 GPM)	X	230	234	4
Granite		234	273	39
Soft zone (NO WATER)		273	282	9
Granite		282	289	7
Small fracture		289	290	1
Granite		290	333	43
Small fracture		333	334	1
Granite		334	363	29
Fracture	X	363	365	2
Granite		365	371	6
Fracture, weathered granite	X	371	387	16

Date started 12-20-85, 19
Date completed 12-27-85, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION

Diameter hole 10 x 6 inches Total depth 387 feet
Casing record 387
Weight per foot Thickness .156

Diameter	From	To
6 5/8 inches	0 feet	299 ~~XXX~~ feet
inches	feet	feet
5 inches	0 feet	387 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type cement
Depth of seal 53 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 53 feet to 387 feet

Perforations:
Type perforation ~~XXXXXXXXXXXX~~ factory sawed slot
Size perforation 3/32 x 2½ x 6 around
From 253 feet to 293 feet
From feet to feet
From 347 feet to 387 feet
From feet to feet
From feet to feet

9. WATER LEVEL

Static water level 171 feet below land surface
Flow 12 G.P.M. P.S.I.
Water temperature cold °F. Quality clear

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Wayne Drilling of Nevada, Inc. (Contractor)

Address P.O. Box 12370, Reno, NV 89510 (Contractor)

Nevada contractor's license number 22549

Nevada contractor's drillers number 908

Nevada driller's license number 923 (Actual Driller)

Signed [signature] (Contractor)

Date December 30, 1985

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 9-81) O-627 C-8453