WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

OFFICE USE ONLY
Log No. 28832
Permit No. 53296
Basin

IN BOOK

NOTICE OF INTENT NO. 4439

OWNER ROBERT TAYLOR
MAILING ADDRESS ST. RT. BOX 71379 PAHRUMP, NEV. 89041

ADDRESS AT WELL LOCATION 225 FT. NORTH OF THOUSANDAIRE + 1/4 MILE WEST OF HOMESTEAD-PAHRUMP

2. LOCATION ¼ S.E. ¼ Sec. 12 T. 21 M/S R. 53 E NYE County

PERMIT NO. — 53296 (Issued by Water Resources) | LOT 10 B (Parcel No.) | HOOLIHAN RANCH (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	1	1
HARD BROWN CALECHE		1	14	13
BROWN CALECHE		14	17	3
HARD BROWN CALECHE		17	25	8
BROWN CALECHE		25	29	4
HARD BROWN CALECHE		29	58	29
BROWN CALECHE		58	65	7
HARD BROWN CALECHE		65	93	28
BROWN CLAY		93	112	19
HARD BROWN CALECHE		112	117	5
BROWN CLAY		117	132	15
HARD BROWN CLAY		132	138	6
BROWN CALECHE		138	160	22

RECEIVED
JAN 29 1988
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 5-6, 1987
Date completed 5-15, 1987

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 12 inches Total depth 160 feet
Casing record 160 FT. 8 5/8" O.D.
Weight per foot 14.11 Thickness .156

Diameter	From	To
12 inches	0 feet	160 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type CEMENT
Depth of seal 50 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from ..... feet to ..... feet

Perforations:
Type perforation TORCH CUT
Size perforation 3/8" X 10"
From 80 feet to 160 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 38 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature ..... ° F. Quality .....

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name RON FLOYD PUMP & DRILLING (Contractor)
Address BOX 157 PAHRUMP, NEV. (Contractor)
Nevada contractor's license number 7479-A
Nevada contractor's drillers number 1424
Nevada driller's license number 1427 STAN HARCAN (Actual Driller)
Signed [signature] (Contractor)
Date 5-15-87

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434