WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 2886 in Book
Permit No. 44295
Basin Q12

1. OWNER George Pitchlus ADDRESS 5009 Valdez Las Vegas Nev.

2. LOCATION SW ¼ SE ¼ Sec. 33 T. 19 N(S) R. 60 E. Clark County
PERMIT NO. 44295

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay & Gravel		0	370	370
Gravel	X	370	400	30

RECEIVED
JUN 8 1981
Div. of Water Resources
Branch Office — Las Vegas, Nev.

Date started 4-8, 19 81
Date completed 4-11, 19 81

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 12 1/4 inches Total depth 400 feet
Casing record
Weight per foot ..... Thickness

Diameter	From	To
8 5/8 inches	+1 feet	400 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 400 feet

Perforations:
Type perforation Factory 8 Rows
Size perforation 1/8
From 340 feet to 400 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 130 Feet below land surface
Flow ..... G.P.M.
Water temperature ..... ° F. Quality Good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Water Well Services
Address 5115 So. Industrial
Nevada contractor's license number 10791
Nevada driller's license number 694
Signed [signature]
Date 5-10-81

USE ADDITIONAL SHEETS IF NECESSARY

O-627