

**WELL DRILLER'S REPORT**

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 9305

1. OWNER DOUGLAS E. LUNDGREN ADDRESS AT WELL LOCATION \_\_\_\_\_  
MAILING ADDRESS 1760 Burnside Dr. 1070 Silver Fox  
Sparks, Nv. 89431 off Dog Valley Rd.  
2. LOCATION NE  $\frac{1}{4}$  SW  $\frac{1}{4}$  Sec. 7 T. 19 N/S R. 18 E Washoe County  
PERMIT NO. \_\_\_\_\_ Parcel No. \_\_\_\_\_  
Issued by Water Resources \_\_\_\_\_ Subdivision Name Sunrise Creek Subdivision

3. TYPE OF WORK  
New Well  Recondition   
Deepen  Other

4. PROPOSED USE  
Domestic  Irrigation  Test   
Municipal  Industrial  Stock

5. TYPE WELL  
Cable  Rotary   
Other  Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
top soil		0	$\frac{1}{2}$	$\frac{1}{2}$
Dark brown clay		$\frac{1}{2}$	9	8 $\frac{1}{2}$
Brown clay w/ boulder & gravels		9	27	18
Dark gray clay w/ boulders		27	80	53
Light gray clay		80	105	25
Blue clays		105	135	30
Soft zone		135	138	3
Blue clays		138	139	1
Light gray clays		139	154	25
Gray basatt		154	173	19
Soft zone ( 2 - 3 GPM)	X	173	175	2
Gray Basatt		175	221	46
Gray fracture basatt		221	223	2
Gray basatt		223	227	4
Soft zone w/ hard streaks.		227	264	37
Soft zone		264	265	1
Gray basatt		265	287	22
Soft zone	X	287	290	3
gray basatt		290	306	16
Soft zone		306	312	6
Gray basatt		312	334	22
Fracture	X	334	336	2
Gray basatt		336	339	3
Soft zone		339	343	4
Gray basatt		343	350	7

Date started 8-18-87, 19\_\_\_\_\_  
Date completed 8-20-87, 19\_\_\_\_\_

8. WELL CONSTRUCTION  
Diameter 6 inches Total depth 350 feet  
Casing record 350 ft. steel casing installed.  
Weight per foot \_\_\_\_\_ Thickness .156

Diameter	From	To
<u>6 5/8</u> inches	<u>0</u> feet	<u>350</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes  No  Type cement  
Depth of seal 51 feet  
Gravel packed: Yes  No   
Gravel packed from 51 feet to 350 feet

Perforations:  
Type perforation Factory sawed slot  
Size perforation 3/32 x 3 x 6 around  
From 276 feet to 299 feet  
From 322 feet to 345 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

9. WATER LEVEL  
Static water level 43 feet below land surface  
Flow 21 G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Wayne Drilling, Inc.  
Address P.O. Box 12370 Reno, Nv. 89510  
Nevada contractor's license number 22549  
issued by the State Contractor's Board  
Nevada contractor's driller's number 908  
issued by the Division of Water Resources  
Nevada driller's license number issued by the 923  
Division of Water Resources, the on-site driller  
Signed Wayne Drilling, Inc.  
By driller performing actual drilling on site or contractor  
Date August 26, 1987

BAILER TEST

G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours