WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 28900
Permit No.
Basin 8-103

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 9388

1. OWNER BILL MILES (MILES Bros Const) ADDRESS AT WELL LOCATION BLOCK 5
MAILING ADDRESS DAYTON, NEVADA 89403 | 10 MARTIN STREET MOUNDHOUSE, NEVADA
2. LOCATION SE ¼ SW ¼ Sec. 29 T. 16 N/S R. 21 E. LYON County
PERMIT NO. | 19-065-05 | SIERRA VIEW ESTATES
Issued by Water Resources | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden w/ blow sand		0	3	3
Cemented gravels w/ sand		3	48	45
Cemented gravels w/ lenses of small gravels		45	92	47
Gravel & sand with 1 GPM water	✓	92	93	1
Cemented gravels		93	97	4
Gravel lenses, various thickness interspersed w/ compacted sand, carrying water	✓	97	120	23
T.D. 120 FT				

Date started Aug 10, 1987
Date completed Aug 11, 1987

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blow well with air to develop and gravel pack			
Making 18-20 GPM from 80'			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 10 3/4 60' inches Total depth 120 feet
..... inches
..... inches
Casing record 6 5/8" O.D.
Weight per foot 11.7 Thickness .156

Diameter	From	To
6 5/8 inches	+2 feet	120 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 53 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 53 feet to 120 feet

Perforations:
Type perforation Factory Mill Slot
Size perforation 3/32 x 3 1/2
From 95 feet to 115 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 34 feet below land surface
Flow 18-20 G.P.M. ..... P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name H & H Pump Co. (Contractor)
Address 5551 Hwy 50E #3 C. City, Nev (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 23295
Nevada contractor's driller's number issued by the Division of Water Resources .....
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1472
Signed Gordon R Butts
By driller performing actual drilling on site or contractor
Date Aug 11, 1987

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627