WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 28902 (I)
Permit No. Domestic
Basin WASHOE V. 6-89

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 8858

1. OWNER Young Enterprizes
MAILING ADDRESS 2270 Spoolshoe Lane Reno, Nevada
ADDRESS AT WELL LOCATION 1955 Lake Shore Drive

2. LOCATION NW ¼ NW ¼ Sec. 31 T. 17 N S.R. 20 E Washoe County
PERMIT NO. W Cty 3073 (Issued by Water Resources) 50-060-06 (Parcel No.) New Washoe City (Subdivision Name)

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden & Sand		0	7	7
Sand & fine silt		7	83	74
Sand with D.G. Stringers	✓	83	100	17
Fractured hard Granodiorite with water	✓	100	121	21
T.D. 121 ft				

Date started Aug 27, 1987
Date completed Aug 28, 1987

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew well with Air to Gravel Pack and develop			
Well Making 25 GPM from 90'			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 11 3/4 inches Total depth 121 feet
..... inches
..... inches
Casing record 6 5/8" O.D.
Weight per foot 11.7 Thickness .156

Diameter	From	To
6 5/8 inches	+2 feet	121 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 57 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 57 feet to 121 feet

Perforations:
Type perforation Factory Mill slot
Size perforation 1/16" X 3 1/2"
From 95 feet to 116 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 16 feet below land surface
Flow 25 G.P.M. ..... P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H Pump Co (Contractor)
Address 5551 Hwy 50E #3 Carson City, Nev (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 23295
Nevada contractor's driller's number issued by the Division of Water Resources .....
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1472
Signed ..... By driller performing actual drilling on site or contractor
Date Aug 28, 1987

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627