WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 28904
Permit No.
Basin 6-89

I

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 8857

1. OWNER Steve Hamilton (D. Wilday)
MAILING ADDRESS 3710 Grant Drive Reno, Nevada
ADDRESS AT WELL LOCATION 7020 Frankfourn Rd

2. LOCATION NE ¼ SW ¼ Sec. 22 T. 16 N/S R. 19 E. Washoe County
PERMIT NO. WCty 3074 (Issued by Water Resources) 55-190-09 (Parcel No.) San Antonio Ranch Estates (Subdivision Name)

3. TYPE OF WORK: New Well ☑ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☑ Irrigation ☐ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☐ Rotary ☑ Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden w/ Boulders and D.G.		0	5	5
Gravels, sand with cobbles interspersed w/ lenses of granite. 1st water (surface) at 6 ft	✓	5	52	47
Granodiorite, medium to hard, no fracture 4.5 GPM	✓	52	183	131
Fractured granite, caving with water	✓	183	217	34
Hard granite		217	220	3
T.D. 220 ft.				

Date started Aug 11, 1987
Date completed Aug 18, 1987

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Developed air with clean water & air to remove drill mud & gravel packs			
Blew 40+ GPM from 180'			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 12 3/4 inches Total depth 220 feet
..... inches
..... inches
Casing record 8 5/8". O.D.
Weight per foot ..... Thickness .188

Diameter	From	To
8 5/8 inches	+2 feet	220 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 70 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 70 feet to 220 feet

Perforations:
Type perforation Factory mill slot
Size perforation 3/32 x 5 1/2
From 178 feet to 212 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 8 feet below land surface
Flow 40+ G.P.M. ..... P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H Pump Co (Contractor)
Address 5551 Hwy 50E #3 Carson City, Nev (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 23295
Nevada contractor's driller's number issued by the Division of Water Resources .....
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1472
Signed [signature] By driller performing actual drilling on site or contractor
Date Aug 21, 1985

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627