WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 28905
Permit No.
Basin 8-104

I

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 9387

1. OWNER Millard Realty & Construction
MAILING ADDRESS 2959 Hiway 50 E Carson City, Nevada
ADDRESS AT WELL LOCATION 3519 Green Clover Drive

2. LOCATION SW ¼ NW ¼ Sec. 7 T. 14 N/S R. 20 E. Douglas County
PERMIT NO. ..... Issued by Water Resources | 13-080-47 Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☑ Replacement

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden with large gravels to 6" and sand		0	4	4
Highly cemented pea gravels		4	160	156
Fractured diorite with lenses of D.G. & water tested @ 5 GPM	✓	160	218	58
Hard diorite		218	227	9
Fractured diorite w/water	✓	227	240	13
T.D. 240'				
see log 28906 for plugging of Log #12725				

Date started Aug 20, 1987
Date completed Aug 25, 1987

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Tested well with pump. Well pumping 12 GPM from 195' at 60 psig thru meter			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 11 1/4 to 60' inches Total depth 240 feet
7 7/8 inches
..... inches
Casing record 6 5/8" O.D.
Weight per foot 11.7 Thickness .156

Diameter	From	To
6 5/8 inches	42 feet	242 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 60 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 60 feet to 240 feet

Perforations:
Type perforation factory Mill Slot
Size perforation 3/32 x 3 1/2
From 212 feet to 232 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 150 feet below land surface
Flow 14 G.P.M. ..... P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H Pump Co. Contractor
Address 3581 Hiway 50 E #3 Carson City, Nev. Contractor
Nevada contractor's license number issued by the State Contractor's Board 23295
Nevada contractor's driller's number issued by the Division of Water Resources .....
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1472
Signed Clinton R Britton
By driller performing actual drilling on site or contractor
Date Aug 26, 1987

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627