



WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 6352

1. OWNER Thomas R. Lowe ADDRESS AT WELL LOCATION 2100 TARZYN LANE FALLON, NEV. 89406
 MAILING ADDRESS 2100 TARZYN LANE FALLON NEVADA 89406
 2. LOCATION S 1/4 NW 1/4 Sec. 8 T. 19 N. 29 E. Churchill County
 PERMIT NO. 10-451-05 Parcel No. _____ Subdivision Name TARZYN PARK ESTATES

3.	TYPE OF WORK	4.	PROPOSED USE	5.	TYPE WELL
	New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>		Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/>		Cable <input checked="" type="checkbox"/> Rotary <input type="checkbox"/>
	Deepen <input type="checkbox"/> Other <input type="checkbox"/>		Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>		Other <input type="checkbox"/>

6. **LITHOLOGIC LOG**

Material	Water Strata	From	To	Thick-ness
SAND		0	1'	1'
CLAY		1'	6'	5'
SAND (FINE)		6'	9'	2'
CLAY + SAND		8'	20'	12'
Black Tule CLAY		20'	51'	31'
GRAY SAND		51'	55'	4'
GRAY CLAY		55'	70'	15'
GRAY SAND (FINE)		70'	90'	20'
BROWN CLAY		90'	100'	10'
BROWN CLAY + SAND		100'	115'	15'
BROWN SAND + GRAVEL	✓	115'	130'	15'
BROWN CLAY		130'		

8. **WELL CONSTRUCTION**

Diameter 6 inches Total depth 130 feet

Casing record _____

Weight per foot _____ Thickness 188

Diameter	From	To
<u>12</u> inches	<u>0</u> feet	<u>50</u> feet
<u>6</u> inches	<u>0</u> feet	<u>130</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type CONCRETE

Depth of seal 50 feet

Gravel packed: Yes No

Gravel packed from _____ feet to _____ feet

Perforations:

Type perforation MACHINED

Size perforation 3/32 x 3

From 120 feet to 130 feet

From _____ feet to _____ feet

Date started Aug 12, 1987
 Date completed Aug 21, 1987

7. **WELL TEST DATA**

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>3450</u>	<u>25</u>	<u>30 ft</u>	<u>8</u>
_____	_____	_____	_____
_____	_____	_____	_____

9. **WATER LEVEL**

Static water level 6 feet below land surface

Flow _____ G.P.M. _____ P.S.I.

Water temperature Cold °F Quality Good

10. **DRILLER'S CERTIFICATION**

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name VERNON CANNON Jr
 Contractor

Address 1870 ROBERSON LN. FALLON
 Contractor

Nevada contractor's license number issued by the State Contractor's Board 23317

Nevada contractor's driller's number issued by the Division of Water Resources 1455

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1455

Signed Vernon Cannon Jr.
 By driller performing actual drilling on site or contractor

Date Aug 21, 1987

BAILER TEST

G.P.M. _____	Draw down _____ feet	_____ hours
G.P.M. _____	Draw down _____ feet	_____ hours
G.P.M. _____	Draw down _____ feet	_____ hours