

OFFICE USE ONLY  
 Log No. 28914  
 Permit No. \_\_\_\_\_  
 Basin 4-72

**WELL DRILLERS REPORT**

Please complete this form in its entirety



1. OWNER ELIZABETH VAN BLITERSWIJK ADDRESS PO Box 74  
IMLAY, NEVADA 89418

2. LOCATION SW 1/4 NE 1/4 Sec. 9 T. 32 N/S R. 34 E PERSHING County  
 PERMIT NO. \_\_\_\_\_

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
TOP SOIL		0	5	5
DRY GRAVEL		5	18	13
CLAY + GRAVEL	23	18	45	37
BROWN CLAY		45	77	32
REDDISH BROWN CLAY WITH STREAKS OF GRAVEL	88	77	90	13
BROWN CLAY STREAK OF HARD WHITE CLAY		90	122	32
FINE GRAVEL/SAND		122	135	13
GRAY CLAY/GRAVEL		135	141	6

8. WELL CONSTRUCTION  
 Diameter hole 8 inches Total depth \_\_\_\_\_ feet  
 Casing record SET TO BOTTOM  
 Weight per foot \_\_\_\_\_ Thickness 188  

Diameter	From	To
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes  No  Type SAFUT  
 Depth of seal 50 FT feet  
 Gravel packed: Yes  No   
 Gravel packed from \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Perforations:  
 Type perforation SAW SLOT  
 Size perforation 1/4 X 2  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 43 Feet below land surface 43  
 Flow \_\_\_\_\_ G.P.M.  
 Water temperature 65 °F. Quality GOOD

Date started AUG 11, 1987  
 Date completed AUG 15, 1987

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name MIKE McMINICH  
 Address PO Box 423  
 Nevada contractor's license number 5437  
 Nevada driller's license number 1040  
 Signed Mike McMinich  
 Date AUG 15 1987

BAILER TEST  
 G.P.M. 20 Draw down 20 feet 3 hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours