



WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 8875

1. OWNER Dominique & Rosemarie Idiart ADDRESS AT WELL LOCATION _____
MAILING ADDRESS 1036 Glen Molly Dr. 5024 Pleasant View Dr.
Sparks, Nv 89431

2. LOCATION NW 1/4 NW 1/4 Sec. 1 T. 19 N/S R. 20 E. Washoe County
PERMIT NO. 030-202-05 — Sunset View Rancho Estates # 2
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
New Well Recondition
Deepen Other

4. PROPOSED USE
Domestic Irrigation Test
Municipal Industrial Stock

5. TYPE WELL
Cable Rotary
Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown clay volcanic rock		0	26	26
Green & brown volcanic rock		26	38	12
Hard green & brown fractured volcanic rock		38	72	34
Green reddish brown white & brown volcanic rock with some brown clay		72	152	80
Green with some brown volcanic rock		152	228	76
Orange purple green yellow & white rock with purple & brown clay		228	267	39
Reddish brown clay volcanic rock		267	275	8
Light brown clay and volcanic rock		275	388	113
Green yellow brown purple red & white volcanic rock	388	388	415	27
T.D. 419'				

8. 10"-60" WELL CONSTRUCTION
Diameter 8 1/2 inches Total depth 404 feet
Casing record 6 5/8 inches
Weight per foot 10.75 & 12.92 Thickness .188 &

Diameter	From	To
<u>6 5/8</u> inches	<u>+2</u> feet	<u>404</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type Grout
Depth of seal 50 feet
Gravel packed: Yes No
Gravel packed from 50 feet to 404 feet

Perforations:
Type perforation factory
Size perforation 3/32 X 3
From 384 feet to 404 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

9. WATER LEVEL
Static water level 330 feet below land surface
Flow 15+ G.P.M. _____ P.S.I.
Water temperature cold °F Quality _____

Date started 8/6/87, 19____
Date completed 8/10/87, 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

Blew with air for 2 1/2 hours to clean and develop.

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Aqua Drilling & Well Service, Inc.
Address 2255 Glendale Ave. Sparks, Nv 89431
Nevada contractor's license number 15291
issued by the State Contractor's Board
Nevada contractor's driller's number 1132
issued by the Division of Water Resources
Nevada driller's license number issued by the 1511
Division of Water Resources, the on-site driller
Signed Roger M. Thrall
By Driller performing actual drilling of site or contractor
Date Roger M. Thrall

BAILER TEST
G.P.M. _____ Draw down _____ feet _____ hours
G.P.M. _____ Draw down _____ feet _____ hours
G.P.M. _____ Draw down _____ feet _____ hours