



**WELL DRILLER'S REPORT**

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 8212

1. OWNER Yoko Baker ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS P. O. Box 18159 1150 Dunbar Dr.  
Reno, Nv 89511  
 2. LOCATION SE 1/4 se 1/4 Sec. 30 T. 17 N/S R. 20 E Washoe County  
 PERMIT NO. 050-253-05 New Washoe City  
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/>	Cable <input type="checkbox"/> Rotary <input checked="" type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>	Other <input type="checkbox"/> <b>AIR</b>

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown clay & D.G. sand		0	22	22
Green yellow brown D.G. with traces of black & white rock and clay		22	47	25
Green brown white decomposed granite	47	47	179	132
T.D. 179'				

8. 10"-100" WELL CONSTRUCTION

Diameter 7 7/8 inches Total depth 179 feet

Casing record 6 5/8 inches

Weight per foot 10.78 & 12.92 Thickness .156 & .188

Diameter	From	To
<u>6 5/8</u> inches	<u>+2</u> feet	<u>179</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes  No  Type grout

Depth of seal 53+ feet

Gravel packed: Yes  No

Gravel packed from 53+ feet to 179 feet

Perforations:

Type perforation factory

Size perforation 3/32 X 3

From 151 feet to 171 feet

From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 7/20/87, 19\_\_\_\_

Date completed 7/22/87, 19\_\_\_\_

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew well with air to clean and develop for 1 1/2 hours.			

BAILER TEST

G.P.M.	Draw down	feet	hours

9. WATER LEVEL

Static water level 40 feet below land surface

Flow 20+ G.P.M. \_\_\_\_\_ P.S.I.

Water temperature cold F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Aqua Drilling & Well Service, Inc.

Address 2255 Glendale Ave. Sparks, Nv 89431

Nevada contractor's license number 15291  
 issued by the State Contractor's Board

Nevada contractor's driller's number 1132  
 issued by the Division of Water Resources

Nevada driller's license number issued by the 1511  
 Division of Water Resources of the on-site driller

Signed Roger M. Thrall  
 By driller performing actual drilling on site or contractor

Date Roger M. Thrall 7/24/87