



DCA

WELL DRILLERS REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 5922

1. OWNER Gary Simpson ADDRESS AT WELL LOCATION Same
 MAILING ADDRESS 1103 Silver Fern
Verdi, Nevada

2. LOCATION NW 1/4 SE 1/4 Sec. 7 T. 19 N/S R. 18 E. Washoe County
 PERMIT NO. 3049 38-291-08 Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Boulders and gravel		0	35	
gray clay		35	280	
gray Rock	291	280	310	
gray clay		310	322	
gray Rock		322	352	
Hard Black Rock		352	391	
soft gray Rock		391	420	
med Hard Black Rock	452	420	460	

8. WELL CONSTRUCTION
 Diameter hole 10 7/8 inches Total depth 460 feet
 Casing record _____
 Weight per foot approx. 9.6 Thickness 1.56
 Diameter From To
6 7/8 od. inches 0 feet 280 feet
5' od inches 275 feet 460 feet
 Surface seal: Yes No Type gravel
 Depth of seal 100+ feet
 Gravel packed: Yes No
 Gravel packed from _____ feet to _____ feet
 Perforations:
 Type perforation factory reamed
 Size perforation 3 3/4 x 1/2
 From 291 feet to 331 feet
 From 420 feet to 460 feet

Date started 7-10 1987
 Date completed 7-16 1987

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

9. WATER LEVEL
 Static water level 50 feet below land surface
 Flow _____ G.P.M. approx. 30
 Water temperature cool ° F. Quality unknown

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Paul Williams & Sons Drilling Contractor
 Address 22 So. Patterson, Sparks, NV Contractor
 Nevada contractor's license number 14483
 Nevada contractor's drillers number 957
 Nevada driller's license number 1287 Actual Driller
 Signed Paul Williams Sr. Contractor
 Date 7-20-87

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours