

**WELL DRILLER'S REPORT**

PRINT OR TYPE ONLY

Please complete this form in its entirety

NOTICE OF INTENT NO. \_\_\_\_\_

1. OWNER Charles Swinsky ADDRESS AT WELL LOCATION Wellington  
MAILING ADDRESS Wellington Nevada 89444 Mesa Drive  
2. LOCATION SE 1/4 NW 1/4 Sec. 23 T. 11 N. R. 23 E. Lyon County  
PERMIT NO. \_\_\_\_\_ Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. TYPE OF WORK  
New Well  Recondition   
Deepen  Other

4. PROPOSED USE  
Domestic  Irrigation  Test   
Municipal  Industrial  Stock

5. TYPE WELL  
Cable  Rotary   
Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Soft brown clay		0	25	25
Sandy clay / some gravel		25	35	10
Coarse sand / heavy gravel	Yes	35	60	25
Fine sand / silt	Yes	60	75	15
Coarse sand / and gravel	Yes	75	117	42

8. WELL CONSTRUCTION  
Diameter 8 inches Total depth 117 feet  
Casing record 117  
Weight per foot \_\_\_\_\_ Thickness 250  
Diameter 8 inches From 0 feet To 117 feet  
Surface seal: Yes  No  Type Concrete  
Depth of seal 50 feet  
Gravel packed: Yes  No   
Perforations Factory Saw Slot  
Type perforation \_\_\_\_\_  
Size perforation 7/32" x 2"  
From 82 feet to 105 feet

9. WATER LEVEL  
Static water level 40 feet below land surface  
Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature 64 °F Quality Good

Date started 7-20- 1987  
Date completed 7-27- 1987

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name EMDL CO. INC. Contractor  
Address Box 92, Smith, Nv. 89430 Contractor  
Nevada contractor's license number issued by the State Contractor's Board 24149  
Nevada contractor's driller's number issued by the Division of Water Resources 24149  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 24149  
Signed Edward Miller By driller performing actual drilling on site of contractor  
Date 7-28-87

BAILER TEST  
G.P.M. 40 Draw down 5 feet 2 hours  
G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours