



WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 6335

1. OWNER WILLIAM L. MOSS ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 11655 Overland Rd. _____
Reno, NV 89506 _____
 2. LOCATION SW $\frac{1}{4}$ NE $\frac{1}{4}$ Sec. 15 T. 21 N/S R. 19 E. Washoe County
 PERMIT NO. 080-395-08 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil		0	2	2
Brown clay		2	6	4
Soft brown clay		6	9	3
Soft brown sandy clay		9	73	64
Soft zone		73	80	7
Soft brown sandy clay		80	124	44
Soft brown sand w/ clay streaks		124	165	41
Decomposed granite		165	170	5
Weathered granite		170	190	20
Soft zone (2 GPM)	X	190	191	1
Weathered granite		191	206	15
Soft zone	X	206	213	7
Weathered granite		213	230	17
Soft zone		230	233	3
Weathered granite		233	237	4
Soft zone	X	237	238	1
Weathered granite		238	241	3
Soft zone w/ clay streaks		241	245	4
Weathered granite		245	250	5

8. WELL CONSTRUCTION

Diameter 6 inches Total depth 250 feet
5 9/16 inches
 _____ inches
 Casing record 250 ft steel casing installed.
 Weight per foot _____ Thickness .156

Diameter	From	To
<u>6 5/8</u> inches	<u>0</u> feet	<u>180</u> feet
<u>5 9/16</u> inches	<u>167</u> feet	<u>250</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type cement
 Depth of seal 51 feet
 Gravel packed: Yes No
 Gravel packed from 51 feet to 250 feet

Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 6 around
 From 187 feet to 250 feet
 From _____ feet to _____ feet

Date started 7-22-87, 19_____
 Date completed 7-23-87, 19_____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL

Static water level 120 feet below land surface
 Flow 18 G.P.M. _____ P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Wayne Drilling, Inc.
 Contractor
 Address P.O. Box 12370 Reno, NV 89510
 Contractor
 Nevada contractor's license number 22549
 issued by the State Contractor's Board
 Nevada contractor's driller's number 908
 issued by the Division of Water Resources
 Nevada driller's license number issued by the 923
 Division of Water Resources, the on-site driller
 Signed Wayne C. Johnson
 By driller performing actual drilling on site or contractor
 Date July 28, 1987