

WELL DRILLER'S REPORT

PRINT OR TYPE ONLY

Please complete this form in its entirety

NOTICE OF INTENT-NO. 7573

1. OWNER Wayne Daniels ADDRESS AT WELL LOCATION 1200 Jones  
 MAILING ADDRESS PO Box 82 Minden NV 89423  
 2. LOCATION SE 1/4 SW 1/4 Sec 3 T 2 R 1 E Douglas County  
 PERMIT NO. 19-390-05 Parcel No. \_\_\_\_\_ Subdivision Name Jones Ranch Acres  
 Issued by Water Resources

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Clay Sand &amp; Gravel</u>		<u>0</u>	<u>5</u>	
<u>Clay &amp; Sand</u>		<u>5</u>	<u>20</u>	
<u>Sand</u>	<input checked="" type="checkbox"/>	<u>20</u>	<u>35</u>	
<u>Sand &amp; Clay</u>	<input checked="" type="checkbox"/>	<u>35</u>	<u>45</u>	
<u>Sand &amp; gravel</u>	<input checked="" type="checkbox"/>	<u>45</u>	<u>50</u>	
<u>Sand gravel &amp; Clay</u>	<input checked="" type="checkbox"/>	<u>50</u>	<u>70</u>	
<u>Sand &amp; gravel</u>	<input checked="" type="checkbox"/>	<u>70</u>	<u>90</u>	
<u>Sand gravel &amp; Clay</u>	<input checked="" type="checkbox"/>	<u>90</u>	<u>105</u>	
<u>Sand &amp; gravel</u>	<input checked="" type="checkbox"/>	<u>105</u>	<u>115</u>	
<u>Sand gravel &amp; Clay</u>	<input checked="" type="checkbox"/>	<u>115</u>	<u>120</u>	

8. WELL CONSTRUCTION  
 Diameter 8 inches Total depth 120 feet  
 Casing record \_\_\_\_\_  
 Weight per foot \_\_\_\_\_ Thickness 250  
 Diameter From To  
8 inches 0 feet 120 feet  
 \_\_\_\_\_ inches \_\_\_\_\_ feet \_\_\_\_\_ feet  
 Surface seal: Yes  No  Type Cement  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Perforations:  
 Type perforation Retainer Perf.  
 Size perforation 3" X 5/32  
 From 100 feet to 120 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 5-4 1987  
 Date completed 5-13 1987

9. WATER LEVEL  
 Static water level 15' feet below land surface  
 Flow 15+ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature 81.0 °F Quality good

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Kawchack Drilling Inc.  
 Address 1578 Chiquita de Minden NV 89423  
 Nevada contractor's license number #021268  
 issued by the State Contractor's Board  
 Nevada contractor's driller's number #1380  
 issued by the Division of Water Resources  
 Nevada driller's license number issued by the #495  
 Division of Water Resources, the on-site driller  
 Signed Michael Allen  
 By driller performing actual drilling on site or contractor  
 Date 5-14-87

BAILER TEST  
 G.P.M. 15+ Draw down 3 feet 1 hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours