

OFFICE USE ONLY  
Log No. 28975  
Permit No. \_\_\_\_\_  
Basin \_\_\_\_\_  
NOTICE OF INTENT NO. 2446

**WELL DRILLER'S REPORT**

Please complete this form in its entirety

*In Book*

OWNER late Snowden  
MAILING ADDRESS \_\_\_\_\_

ADDRESS AT WELL LOCATION \_\_\_\_\_

2. LOCATION SE 1/4 NW 1/4 Sec 17 T20 S N15 R 53 E Nye County  
PERMIT NO. Lot 257 Vegas Ranchos Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/>	Cable <input type="checkbox"/> Rotary <input checked="" type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>	Other <input type="checkbox"/>

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Hard Pan		0	4	4
Pop Corn shale		4	12	8
Clay		12	47	35
Clay clechic	x	47	51	4
Clay		51	97	46
Clay clechic	x	97	101	4
Clay		101	137	36
Clay clechic	x	137	141	4
Clay + Gravel		141	160	19

8. WELL CONSTRUCTION

Diameter 12 1/4 inches Total depth 160 feet

Casing record 8 3/8 x 160

Weight per foot 14.50 Thickness 1.56

Diameter	From	To
<u>8 3/8</u> inches	<u>0</u> feet	<u>120</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes  No  Type Cement

Depth of seal 50 feet

Gravel packed: Yes  No

Gravel packed from 50 feet to 160 feet

Perforations:

Type perforation Touch

Size perforation 1/2 x 6 2 Rows

From \_\_\_\_\_ feet to \_\_\_\_\_ feet

RECEIVED  
AUG 26 1987  
Div. of Water Resources  
Branch Office - Las Vegas, NV

Date started 5 25, 1987  
Date completed 5 26, 1987

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

9. WATER LEVEL

Static water level 40 feet below land surface

Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.

Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Custom Drilling Inc Contractor

Address 4475 Stacey Ave LV Neo Contractor

Nevada contractor's license number issued by the State Contractor's Board 19219

Nevada contractor's driller's number issued by the Division of Water Resources \_\_\_\_\_

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1081

Signed [Signature]  
By driller performing actual drilling on site or contractor

Date 5 30 -87

BAILER TEST

G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours