[redacted]—DIVISION OF WATER RESOURCES
[redacted]Y—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 28982
Permit No.
Basin 212

1. OWNER INCA Const Duayne Dunn ADDRESS Lamb & Oquendo Las Vegas, Nev

NW NW 32

2. LOCATION ~~NE~~ ¼ ~~NE~~ ¼ Sec. ~~31~~ T. 21 N/S R. 62 E. Clark County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Clay		0	15	15
Gray Clay		15	85	70
Gray hard Pan		85	130	45
Gravel		130	175	45
Red Clay		175	250	75

RECEIVED
OCT 1 1978
Div. of Water Resources
Branch Office — Las Vegas, Nev.

Date started Sept 20, 1978
Date completed Oct 5, 1978

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 20 Draw down 0 feet 1 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 12" inches Total depth 25' feet
Casing record 8" 8"+6" 75-250
Weight per foot 8= 12.15 6= 9.32 Thickness .134

Diameter	From	To
8" inches	0 feet	140 feet
6" inches	130 feet	250 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 50 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from feet to feet

Perforations:
Type perforation Factory Sawed
Size perforation 1/8 x 3
From 190 feet to 250 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 20' Feet below land surface
Flow G.P.M.
Water temperature 69 °F. Quality Fair

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Vincent Dresden
Address 2720 Beechwood Pl Lv.
Nevada contractor's license number 13577
Nevada driller's license number 968
Signed Vince Dresden
Date Oct 11, 78

USE ADDITIONAL SHEETS IF NECESSARY

5471

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

in Book

Log No. 28982 ONLY
Permit No.
Basin

1. OWNER INCA Const Duayne Dunn ADDRESS Lamb & Oquendo Las Vegas, Nev

2. LOCATION NE ¼ NE ¼ Sec. 31 T. 21 N/S R. 62 E. Clark County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Clay		0	15	15
Gray Clay		15	85	70
Gray hard Pan		85	130	45
Gravel		130	175	45
Red Clay		175	250	75

RECEIVED
OCT 16 1978
Div. of Water Resources
Branch Office — Las Vegas, Nev.

Date started Sept 20, 1978
Date completed Oct 5, 1978

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 20 Draw down 0 feet 1 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 12" inches Total depth 75' feet
Casing record 8" 8"+6" 75-250
Weight per foot 8= 12.15 6= 9.32 Thickness .134

Diameter	From	To
8" inches	0 feet	140 feet
6" inches	130 feet	250 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 50 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from feet to feet

Perforations:
Type perforation Factory Sawed
Size perforation 1/8 x 3
From 190 feet to 250 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 20' Feet below land surface
Flow G.P.M.
Water temperature 69 °F. Quality Fair

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Vincent Dresden
Address 2720 Beechwood Pl Lv.
Nevada contractor's license number 13577
Nevada driller's license number 968
Signed Vince Dresden
Date Oct 11, 78

USE ADDITIONAL SHEETS IF NECESSARY

5471

DIVISION OF WATER RESOURCES

In Book

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 28983
Permit No.
Basin 212

1. OWNER Exca Const Dwayne Daum ADDRESS Lamb + Ogwendo

NW NW 32

2. LOCATION ~~NE~~ ¼ ~~NE~~ ¼ Sec. ~~31~~ T. 21 N/S R. 62 E. Clark County

PERMIT NO.

3. TYPE OF WORK				4. PROPOSED USE				5. TYPE WELL	
New Well	☒	Recondition	☐	Domestic	☒	Irrigation	☐	Cable	☒
Deepen	☐	Other	☐	Municipal	☐	Industrial	☐	Rotary	☐
						Stock	☐	Other	☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
gray Clay		0	47	47
Sand	x	47	105	58
Red Clay	x	105	250	145

RECEIVED
Div. of Water Resources
Branch Office — Las Vegas, Nev.

Date started 3-28, 1978
Date completed 4-4, 1978

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. 50 Draw down 0 feet 1 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION

Diameter hole 12 inches Total depth 100 feet
Casing record 8" 8"6" 100-250
Weight per foot 8-12015 6-9.32 Thickness .134

Diameter		From		To	
8	inches	0	feet	140	feet
6"	inches	140	feet	250	feet
	inches		feet		feet
	inches		feet		feet
	inches		feet		feet
	inches		feet		feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 50' feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 140 feet
around 8" to hold cement

Perforations:
Type perforation Factory Sawed
Size perforation 1/8 x 3

From 150 feet to 250 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL

Static water level 20' Feet below land surface
Flow G.P.M.
Water temperature 70 °F. Quality ?

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Vincent Dresden
Address 2920 Beech wood Pl Las Vegas
Nevada contractor's license number 13577
Nevada driller's license number 968
Signed Vincent J Dresden
Date 4-16-78

USE ADDITIONAL SHEETS IF NECESSARY

5471