

**WELL DRILLER'S REPORT**

Please complete this form in its entirety

PRINT OR TYPE ONLY

1. OWNER Clark Co Sanitation Dist ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS \_\_\_\_\_  
 2. LOCATION NW 1/4 SE 1/4 Sec. 14 T. 32 N. 66 E. Clark County  
 PERMIT NO. \_\_\_\_\_ Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_



3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG FW-3

Material	Water Strata	From	To	Thick-ness
Fill material Gravel		0	22	
SAND with some gravel		22	85	
Clay w/ SAND		85	95	
Clay / SAND / Gravel layers		95	125	
SAND w/ some clay gravel		125	155	
Gravels and SAND		155	195	

8. WELL CONSTRUCTION  
 Diameter 6 1/4 inches Total depth \_\_\_\_\_ feet  
 \_\_\_\_\_ inches  
 \_\_\_\_\_ inches  
 Casing record PVC Sched 40  
 Weight per foot \_\_\_\_\_ Thickness \_\_\_\_\_  

Diameter	From	To
<u>2"</u> inches	<u>0</u> feet	<u>191</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes  No  Type Cement  
 Depth of seal 102 feet  
 Gravel packed: Yes  No   
 Gravel packed from 104 feet to 191 feet  
 Perforations:  
 Type perforation Slotted PVC  
 Size perforation .020  
 From 113 feet to 182 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

RECEIVED  
 SEP 24 1987  
 Div. of Water Resources  
 Branch Office - Las Vegas, NV

Date started 5-5, 19 87  
 Date completed 5-5, 19 87

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

9. WATER LEVEL  
 Static water level 154 feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name AAA Pop & Drilling Contractor  
 Address 801 3/4 N. W. 2nd St. Clark 84752 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 0518239  
 Nevada contractor's driller's number issued by the Division of Water Resources 811  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 811  
 Signed Steven R. G. [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 8/25/87

