WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 29088
Permit No.
Basin 8-105

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 8999

1. OWNER SCOTT McDONALD
MAILING ADDRESS 1560 JOHNSON LANE MINDEN, NEVADA
ADDRESS AT WELL LOCATION 1560 JOHNSON LANE MINDEN, NEVADA

2. LOCATION SE ¼ SW ¼ Sec. 34 T. 14 N/S R. 20 E. DOUGLAS County
PERMIT NO. (Issued by Water Resources) 21-224-16 (Parcel No.) (Subdivision Name)

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐ MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
OVERBURDEN & BLOW SAND		0	4	4
SAND, LOOSE, FINE GRAINED		4	117	113
CLAY W/SAND		117	119	2
COURSE TO SMALL GRAVELS W/ SAND + WATER	L	119	150	31
NOTE: BLANK CASING ON BOTTOM IS FULL OF PEA GRAVEL TO STOP SAND FROM COMING IN.				

Date started SEPT 21, 1987
Date completed SEPT 23, 1987

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
DEVELOPED WELL WITH CLEAN WATER TO REMOVE DRILL MUD & GRAVEL PACK 18+ GPM FROM 135' WITH AIR			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 10 3/4 inches Total depth 150 feet
..... inches
..... inches
Casing record 6 5/8" O.D.
Weight per foot 11.7 Thickness .156

Diameter	From	To
6 5/8 inches	+2 feet	150 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 53 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 53 feet to 150 feet

Perforations:
Type perforation FACTORY MILL SLOT
Size perforation 3/32 x 3 1/2
From 127 feet to 145 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 112 feet below land surface
Flow 18+ G.P.M. ..... P.S.I.
Water temperature Cool °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H Pump Co. (Contractor)
Address 5551 Hwy 50E #3 C. City, NV (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 23295
Nevada contractor's driller's number issued by the Division of Water Resources .....
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1472
Signed [signature] (By driller performing actual drilling on site or contractor)
Date SEPT 24, 1987

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627