

OFFICE USE ONLY
 Log No. 20059
 Permit No. 52397, 52398
 Basin 06-089 Washoe V.

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 8755

1. OWNER JIM KIETH ADDRESS AT WELL LOCATION 3265 East Lake Blvd.
 MAILING ADDRESS P.O. Box 1072 Carson City, NV
Verdi, NV 89439
 2. LOCATION SW 1/4 SW 1/4 Sec. 32 T 17N N/S R. 20 E Washoe County
 PERMIT NO. 48915 Issued by Water Resources Parcel No. 050-411-15 Subdivision Name Washoe Valley

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Quasi Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other Air/Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Light brown sand		0	11	11
Rusty brown sandy clay		11	38	27
Weathered granite		38	55	17
Weathered granite with clay streaks		55	79	24
Weathered Granite		79	83	4
Hard gray granite		83	106	23
Weathered granite, soft	X	106	109	3
Hard gray granite		109	186	77
Weathered granite, soft	X	186	196	10
Hard gray granite		196	307	111
Fracture, granite	X	307	323	16
Gray granite		323	330	7

8. WELL CONSTRUCTION
 Diameter 6 inches Total depth 330 feet
 Casing record 330' steel casing installed.
 Weight per foot _____ Thickness .156

Diameter	From	To
<u>6 5/8</u> inches	<u>0</u> feet	<u>330</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type cement
 Depth of seal 52 feet
 Gravel packed: Yes No
 Gravel packed from 52 feet to 330 feet

Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 6 around
 From 225 feet to 245 feet
 From 265 feet to 285 feet
 From 305 feet to 325 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Date started 9-17-87, 19____
 Date completed 9-23-87, 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL
 Static water level 58 feet below land surface
 Flow 65 G.P.M. P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Wayne Drilling, inc. Contractor
 Address P.O. box 12370, Reno, NV 89510 Contractor
 Nevada contractor's license number 22549 issued by the State Contractor's Board
 Nevada contractor's driller's number 908 issued by the Division of Water Resources
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
 Signed [Signature] By driller performing actual drilling on site or contractor
 Date September 28, 1987