WHITE–DIVISION OF WATER RESOURCES
CANARY–CLIENT'S COPY
PINK–WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 29060
Permit No.
Basin 6-83

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 9488

1. OWNER John Ollson
MAILING ADDRESS 14685 Seminole
Reno, Nv 89511

ADDRESS AT WELL LOCATION 2186 Highland Rd
Lot 5 Block U

2. LOCATION NE ¼ NW ¼ Sec. 8 T. 17 N/S R. 21 E. Washoe County
PERMIT NO. — (Issued by Water Resources) 3-191-25 (Parcel No.) Virginia City Highlands (Subdivision Name)

3. TYPE OF WORK: New Well XX; Recondition ☐; Deepen ☐; Other ☐

4. PROPOSED USE: Domestic XX; Irrigation ☐; Test ☐; Municipal ☐; Industrial ☐; Stock ☐

5. TYPE WELL: Cable ☐; Rotary XX; Other ☐ Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown white & yellow volcanic rock		0	29	29
Blue gray yellow brown & white rock		29	72	43
Brown yellow white rock with some yellow clay		72	116	44
Light blue yellow & brown rock		116	134	18
Light blue white green traces of gray clay		134	175	41
Bright green rock with black & white specs	175	175	198	23
T.D. 198				

Date started 9/24/87, 19
Date completed 9/25/87, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew with air for 1½ hrs to clean & develop			

BAILER TEST
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours

8. WELL CONSTRUCTION
Diameter 10" - 60' 8½ inches Total depth 198 feet
inches
inches
Casing record 6 5/8
Weight per foot 10.78 Thickness .156

Diameter	From	To
6 5/8 inches	+2 feet	198 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes X No ☐ Type grout
Depth of seal feet
Gravel packed: Yes X No ☐
Gravel packed from 53 feet to 198 feet

Perforations:
Type perforation factory
Size perforation 3/32 X 3
From 178 feet to 198 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 125 feet below land surface
Flow 15+ G.P.M. P.S.I.
Water temperature cold °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Aqua Drilling & Well Service, Inc. (Contractor)
Address 625 Spice Islands Drive Suite L Sparks, Nv 89431 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 15291
Nevada contractor's driller's number issued by the Division of Water Resources 1132
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1511
Signed Roger M. Thrall (By driller performing actual drilling on site or contractor)
Date Roger M. Thrall 9/28/87

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (0-027)