

OFFICE USE ONLY
 Log No. 29063
 Permit No. _____
 Basin. 6-83

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 7962

1. OWNER Larry Rand
 MAILING ADDRESS 1413 5th St. Sparks, NV 89431
 ADDRESS AT WELL LOCATION 2384 Cartwright Lot 11 Block C
 2. LOCATION NW 1/4 NW 1/4 Sec. 32 T. 18 N/S R. 21 E. Storey County
 PERMIT NO. 003-021-01 - Virginia City Highlands
 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Purple Clay with some purple & white volcanic rock		0	42	42
Purple white brown & yellow volcanic rock		42	54	12
Light green clay with green white & black rock		54	73	19
Green dark brown & white rock		73	115	42
Purple & white fractured rock		115	148	33
Purple white with some green & brown		148	199	51
T.D. 199				

8. 10"-60" WELL CONSTRUCTION
 Diameter 8 1/2 inches Total depth 199 feet
 Casing record 6 5/8 inches
 Weight per foot 10.78 Thickness .156
 Diameter 6 5/8 inches From +2 feet To 199 feet
 Surface seal: Yes No Type grout
 Depth of seal 56 feet
 Gravel packed: Yes No
 Gravel packed from 56 feet to 199 feet
 Perforations:
 Type perforation factory
 Size perforation 3/32 X 3
 From 179 feet to 199 feet
 From _____ feet to _____ feet

Date started 8/12/87, 19____
 Date completed 8/14/87, 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew with air for 2 hours to clean and develop.			

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. 57 WATER LEVEL
 Static water level _____ feet below land surface
 Flow 15 cold G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Aqua Drilling & Well Service, Inc.
 Address 2255 Glendale Ave. Sparks, NV 89431
 Nevada contractor's license number 15291 issued by the State Contractor's Board
 Nevada contractor's driller's number 1132 issued by the Division of Water Resources
 Nevada driller's license number issued by the 1511 Division of Water Resources, the on-site driller
 Signed Roger M. Merrill
 Date 8/26/87