



WELL DRILLER'S REPORT

PRINT OR TYPE ONLY

Please complete this form in its entirety

NOTICE OF INTENT NO. 9524

1. OWNER Paul Basso ADDRESS AT WELL LOCATION 2400 Enterprise
 MAILING ADDRESS 235 Crampton Lot 68 Block H
Reno, Nv 89502

2. LOCATION NW NE 1/4 Sec. 32 T. 18 N/S R. 21 E. Storey County
 PERMIT NO. 03-033-25 - Virginia City Highlands Subdivision Name
 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Hard brown clay		0	3	3
Yellow & gray clay		3	7	4
Brown clay		7	52	45
Black green & white rock		52	135	83'
Red & brown clay		135	141	6
Gray & green clay		141	158	17
Red & Brown clay		158	173	15
Green & white specs soft rock		173	210	37
Green brown & white volcanic rock		210	220	10
Green gray with white specs volcanic rock		220	250	30
Green clay with green gray & white volcanic rock		250	255	5
gray & white clay		255	260	5
green clay with gray rock with white specs		260	305	45
Green rock with white specs, some purple & brown	X	305	338	33
T.D. 338				

8. 10"-60" WELL CONSTRUCTION
 Diameter 8 1/2 inches Total depth 338 feet
 Casing record 6 5/8 inches
 Weight per foot 10.78 Thickness .156

Diameter	From	To
<u>6 5/8</u> inches	<u>+2</u> feet	<u>338</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type grout
 Depth of seal 54 feet
 Gravel packed: Yes No
 Gravel packed from 54 feet to 338 feet

Perforations:
 Type perforation factory
 Size perforation 3/32 X 3
 From 318 feet to 338 feet
 From _____ feet to _____ feet

Date started 10/16/87, 19____
 Date completed 10/20/87, 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

Blew with air to clean and develop.

BAILER TEST

G.P.M.	Draw down	feet	hours

9. 55 WATER-LEVEL
 Static water level 20+ feet below land surface
 Flow 20+ G.P.M. P.S.I.
 Water temperature cold °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Aqua Drilling & Well Service, Inc.
 Address 625 Spice Islands Dr Suite L Sparks, Nv 89431
 Nevada contractor's license number 15291
 issued by the State Contractor's Board
 Nevada contractor's driller's number 1132
 issued by the Division of Water Resources
 Nevada contractor's license number issued by the Division of Water Resources, the on-site driller. 1511/1132
 Signed Roger M. Thrall
 By driller performing actual drilling on site or contractor
 Date 10/26/87