

OFFICE USE ONLY
 Log No. 29218
 Permit No. _____
 Basin 7-923

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 9556

1. OWNER BOB EBERT ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 11615 Oregon Blvd. Same
Reno, NV 89506

2. LOCATION NE 1/4 NE 1/4 Sec. 15 T. 21N N/S R. 19 E Washoe County
Lemmon Valley
 PERMIT NO. _____ Issued by Water Resources _____ Parcel No. _____ Subdivision Name _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
WELL DEEPENING:				
Tested before drilling deeper Yield 2 GPM				
Brown soft thick sand		187	229	42
Decomposed granite		229	230	1
Gray green hard granite		230	247	17
Fractured		247	248	1
Gray green hard granite		248	251	3
Fracture		251	253	2
Green granite		253	258	5
Fracture		258	260	2
Green granite		260	263	3
Fracture granite	X	263	279	16
Green granite		279	295	16

8. WELL CONSTRUCTION

Diameter _____ inches Total depth 295 feet
 _____ inches
 _____ 5 inches Casing from 10' to 295'
 Casing record 5" liner 10' below 6 5/8" at top.
 Weight per foot _____ Thickness 1.34

Diameter	From	To
<u>5" liner</u> inches	<u>10</u> feet	<u>295</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type N/A
 Depth of seal _____ feet
 Gravel packed: Yes No
 Gravel packed from 170 feet to 295 feet

Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 6 around
 From 195 feet to 289 feet
 From _____ feet to _____ feet

Date started 10-12-87, 19____
 Date completed 10-15-87, 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL

Static water level 162 feet below land surface
 Flow 9 G.P.M. _____ P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Wayne Drilling, Inc.
 Address P.O. box 12370, Reno, Nv 89510
 Nevada contractor's license number issued by the State Contractor's Board 22549
 Nevada contractor's driller's number issued by the Division of Water Resources 908
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date October 21, 1987