

OFFICE USE ONLY  
 Log No. 29262  
 Permit No. \_\_\_\_\_  
 Basin AP-Elko Segment  
 NOTICE OF INTENT NO. 8766

**WELL DRILLER'S REPORT**

Please complete this form in its entirety

PRINT OR TYPE ONLY

1. OWNER Fred & Connie Bradley ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS P.O. Box 2761 \_\_\_\_\_  
Elko, NV 89801 \_\_\_\_\_  
 2. LOCATION NE 1/4 NE 1/4 Sec. 7 T 34 N/SR 55 E Elko County \_\_\_\_\_  
 PERMIT NO. \_\_\_\_\_ Lot 2 Block 1 Crestview \_\_\_\_\_  
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/>	Cable <input type="checkbox"/> Rotary <input checked="" type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>	Other <input type="checkbox"/>

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0'	1'	1'
Clay soil & gravel		1'	5'	4'
Gravel w/clay		5'	45'	40'
Clay w/some gravel		45'	100'	55'
Claystone w/some clay sand and gravel		100'	220'	120'
Sandstone w/clay, sand and gravel		220'	250'	30'
Coarse sand to fine gr.		250'	340'	90'
Fine gravel w/thin layer of sandstone		340'	410'	70'
Coarse sand, fine gr.		410'	560'	150'
Gravel		560'	581'	21'
First water at about 485'				

On 11-8-87 installed a Grundfos SP2-46 3 HP 230 volt 0 pump at 550 ft. On one inch drop pipe. Set in a one inch pitless adapter. 6-3 wire used

8. WELL CONSTRUCTION

Diameter 10 inches Total depth 581 feet

Casing record \_\_\_\_\_  
 Weight per foot \_\_\_\_\_ Thickness 156

Diameter	From	To
_____ inches	<u>+2.5</u> feet	<u>536</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes  No  Type cement  
 Depth of seal 4 to 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from 50 feet to 581 feet

Perforations:  
 Type perforation Hand perforated with torch  
 Size perforation 1/8" x 3" 6 row

From	To
<u>536</u> feet	<u>581</u> feet
_____ feet	_____ feet
_____ feet	_____ feet
_____ feet	_____ feet
_____ feet	_____ feet

Date started 10-3, 1987  
 Date completed 10-9, 1987

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blow Test	<u>25</u>		

9. WATER LEVEL

Static water level 485 feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name HACKWORTH DRILLING, INC. Contractor  
 Address P.O. Box 850 Elko, NV 89801 Contractor  
 Nevada contractor's license number 020582 issued by the State Contractor's Board  
 Nevada contractor's driller's number 1166 issued by the Division of Water Resources  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1166  
 Signed Dale C. Nelson By driller performing actual drilling on site or contractor  
 Date 11-10-87

BAILER TEST

G.P.M.	Draw down	feet	hours
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____