

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 9701

1. OWNER PINSON MINING COMPANY ADDRESS AT WELL LOCATION
MAILING ADDRESS P. O. BOX 192 ABOVE PIT - DEWATERING WELL Well 9
WINNEMUCCA, NEVADA 89445
2. LOCATION NW 1/4 SW 1/4 Sec 28 T 38 N S R. 42 E HUMBOLDT County
PERMIT NO. W-243/51390 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK	4. PROPOSED USE	PW#9	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/>		Cable <input type="checkbox"/> Rotary <input checked="" type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Municipal <input type="checkbox"/> Industrial <input checked="" type="checkbox"/> Stock <input type="checkbox"/>		Other <input type="checkbox"/>

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
sand w/broken rock		0	40	40
sand & clay		40	50	10
sand & small gravel		50	62	12
black muck clay, med. gravel, sand, L.C.		62	86	14
black shale rock & some quartz interbedded		86	130	44
black shale rock - fairly soft		130	315	185
black hard rock w/layers solid & fractured		315	485	170
clay & broken rock		485	530	45
gray & black rock & clay		530	610	80
black rock little clay		610	690	80
black shale rock hard		690	750	
<i>Well destroyed by pit wall</i>				
<i>Failure see replacement</i>				
<i>log # 30731 32482</i>				

8. WELL CONSTRUCTION

Diameter 13-7/8 inches Total depth 750 feet
12-1/4 inches
Casing record 8-5/8" O.D. x 1/4" wall
Weight per foot 22.36 Thickness
Diameter From To
14 - 8 inches +1 feet 430 feet
12 - 8 inches 430 feet 750 feet
Surface seal: Yes No Type cement sand grout
Depth of seal 50 feet
Gravel packed: Yes No
Gravel packed from 50 feet to 750 feet
Wadsworth 6/27" well rock
Perforations:
Type perforation Milled
Size perforation 3" x 3/32" dbl std spacing
From 190 feet to 750 feet

Date started OCTOBER 22, 1987
Date completed NOVEMBER 6, 1987

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
air lift	150		10

BAILER TEST

G.P.M.	Draw down	feet	hours

9. WATER LEVEL

Static water level 196 feet below land surface
Flow G.P.M. P.S.I.
Water temperature 66 °F Quality good

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
Name SARGENT IRRIGATION COMPANY
Address 9955 N. VIRGINIA ST. RENO, NV 89506
Nevada contractor's license number 21246
Nevada contractor's driller's number 1391
Nevada driller's license number issued by the Division of Water Resources 1491
Signed [Signature]
By driller performing actual drilling on site or contractor
Date NOVEMBER 13, 1987