

OFFICE USE ONLY  
Log No. 29307  
Permit No. PLUGGED  
Basin 101-CARSON DESERT  
NOTICE OF INTENT NO. 8965

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

1. OWNER DARREL ELLIS ADDRESS AT WELL LOCATION Same as owner  
MAILING ADDRESS 3675 Hillsboro Blvd  
Fallon, NV 89406  
2. LOCATION SE 1/4 SE 1/4 Sec 9 T 19 N/S R 28 E Churchill County  
PERMIT NO. Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK  
New Well  Recondition   
Deepen  Other   
4. PROPOSED USE  
Domestic  Irrigation  Test   
Municipal  Industrial  Stock   
5. TYPE WELL  
Cable  Rotary   
Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>OVERBURDEN</u>		<u>0</u>	<u>7</u>	<u>7</u>
<u>CLAY, Brown + Sand</u>		<u>7</u>	<u>21</u>	
<u>CLAY, Brown, Hard</u>		<u>21</u>	<u>65</u>	
<u>Sand + clay mixed</u>		<u>65</u>	<u>67</u>	<u>2</u>
<u>CLAY, GRAY</u>		<u>67</u>	<u>80</u>	
<u>Sand + clay, GRAY</u>	<u>20</u>	<u>80</u>	<u>90</u>	<u>10</u>
<u>Static would not hold.</u>				
<u>Sand, GRAY</u>	<u>24</u>	<u>90</u>	<u>91</u>	<u>1</u>
<u>GRAVEL, GRAY "test bed"</u>	<u>24</u>	<u>91</u>	<u>98</u>	<u>7</u>
<u>CLAY, Brown</u>	<u>0</u>	<u>98</u>	<u>113</u>	
<u>CLAY + SAND, Brown</u>		<u>113</u>	<u>118</u>	<u>5</u>
<u>Sand, Fine, GRAY</u>		<u>118</u>	<u>119</u>	<u>1</u>
<u>Sand + clay, GRAY</u>		<u>119</u>	<u>125</u>	
<u>CLAY, GRAY</u>		<u>125</u>	<u>145</u>	
<u>CLAY, Black</u>		<u>145</u>	<u>152</u>	
<u>Sand, Brown + CLAY</u>		<u>152</u>	<u>158</u>	

"NOTE"  
This hole was abandoned. All casing was removed and hole sealed with neat cement to ground surface. Another hole was drilled, but were waiting on test results before completing well.

8. WELL CONSTRUCTION  
Diameter \_\_\_\_\_ inches Total depth \_\_\_\_\_ feet  
Casing record \_\_\_\_\_ inches  
Weight per foot \_\_\_\_\_ Thickness \_\_\_\_\_  
Diameter \_\_\_\_\_ From \_\_\_\_\_ To \_\_\_\_\_  
Surface seal: Yes  No  Type NEAT  
Depth of seal \_\_\_\_\_ feet  
Gravel packed: Yes  No   
Gravel packed from \_\_\_\_\_ feet to \_\_\_\_\_ feet  
Perforations:  
Type perforation \_\_\_\_\_  
Size perforation \_\_\_\_\_  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
Static water level \_\_\_\_\_ feet below land surface  
Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature \_\_\_\_\_ °F Quality 3.5 MA9

Date started 10-26 19 87  
Date completed 11-20 19 87

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>2600</u>			
<u>NONE</u>			

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Water-Rite Well Drilling Contractor  
Address P.O. Box 883 Fallon, NV 89406 Contractor  
Nevada contractor's license number issued by the State Contractor's Board 0023978  
Nevada contractor's driller's number issued by the Division of Water Resources 1475  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1475  
Signed Harold H. Olson By driller performing actual drilling on site or contractor  
Date 11-25-87

BAILER TEST  
G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours