WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 28328
Permit No.
Basin 8-105

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 9391

1. OWNER Ray Sorensen
MAILING ADDRESS Gardnerville, Nevada
ADDRESS AT WELL LOCATION 2247 Calle Hermosa
1485 Via Maximillian
Gardnerville, Nevada

2. LOCATION SW ¼ SW ¼ Sec. 32 T. 13 N/S R. 21 E Douglas County
PERMIT NO. (Issued by Water Resources) 23-180-33 (Parcel No.) None (Subdivision Name)

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden w/ rock & small boulders		0	3	3
Cemented gravels & boulders		3	115	112
Gravels, fine to 1", carrying water	✓	115	140	25
T.D. 140 feet				

Date started Nov 9, 1987
Date completed Nov 10, 1987

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Flushed with clear water to gravel pack & develop			
25-30 GPM from 90'			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 12¼ inches Total depth 140 feet
..... inches
..... inches
Casing record 8 5/8"
Weight per foot ..... Thickness .25

Diameter	From	To
8 inches	+2 feet	140 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Portland Cement
Depth of seal 53 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 53 feet to 140 feet

Perforations:
Type perforation Factory Mill Slot
Size perforation 3/32 x 3½
From 100 feet to 140 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level ..... feet below land surface
Flow 25-30 G.P.M. ..... P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name J. H. Pump Co. (Contractor)
Address 5551 Hwy 50 E Carson City, Nev (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 23295
Nevada contractor's driller's number issued by the Division of Water Resources .....
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1477
Signed ..... (By driller performing actual drilling on site or contractor)
Date Nov 12, 1987

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627