



**WELL DRILLER'S REPORT**

Please complete this form in its entirety

NOTICE OF INTENT NO. \_\_\_\_\_

PRINT OR TYPE ONLY

1. OWNER John Fitzgerald ADDRESS AT WELL LOCATION 1927 JUNGO CT.  
 MAILING ADDRESS Box 3314 Incline Village,  
NV 89450  
 2. LOCATION NW 1/4 SE 1/4 Sec. 12 T. 12 N. R. 20 E Douglas County  
 PERMIT NO. \_\_\_\_\_ Issued by Water Resources | Lot 6 Parcel No. | Sagewood Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock  Other   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Aluvial</u>		<u>0</u>	<u>1</u>	<u>1</u>
<u>Boulders</u>		<u>1</u>	<u>6</u>	<u>5</u>
<u>Sand, gravel, and occ. boulders</u>		<u>6</u>	<u>30</u>	<u>24</u>
<u>Small Boulders (hard)</u>		<u>30</u>	<u>36</u>	<u>6</u>
<u>Gravel- 1/2" +/- occ. large rocks &amp; boulders</u>		<u>36</u>	<u>78</u>	<u>42</u>
<u>Clavey sand &amp; gravel (soft) rocks (boulders)</u>		<u>84</u>	<u>99</u>	<u>15</u>
<u>Alternating soft clayey gravel w/ small cobbles &amp; gravels &amp; harber</u>		<u>99</u>	<u>103</u>	<u>4</u>
<u>Hard clay</u>		<u>103</u>	<u>138</u>	<u>35</u>
<u>Clavey gravel w/cobbles</u>		<u>138</u>	<u>146</u>	<u>8</u>
<u>Gravel &amp; small cobbles</u>		<u>146</u>	<u>155</u>	<u>9</u>
<u>Alternating gravel &amp; sands</u>		<u>155</u>	<u>167</u>	<u>12</u>
<u>Boulders (hard)</u>		<u>167</u>	<u>210</u>	<u>43</u>
		<u>210</u>	<u>240</u>	<u>30</u>

8. WELL CONSTRUCTION  
 Diameter 11 inches Total depth 240 feet  
 Casing record \_\_\_\_\_  
 Weight per foot \_\_\_\_\_ Thickness 156  
 Diameter From To  
6 inches 0 feet 240 feet  
 \_\_\_\_\_ inches \_\_\_\_\_ feet \_\_\_\_\_ feet  
 Surface seal: Yes  No  Type grout  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from 245 feet to 50 feet  
 Perforations:  
 Type perforation saw-cut  
 Size perforation 1/8" x 2 1/2"  
 From 200 feet to 240 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started Aug. 4, 1987  
 Date completed Aug. 12, 1987

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>Air lift</u>	<u>10 GPM</u>		<u>2 hours</u>
<u>Air line set at 200</u>			

BAILER TEST  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

9. WATER LEVEL  
 Static water level 146 feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Oasis Drilling Inc. Contractor  
 Address Box 2008 Gardnerville, NV Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 0023129  
 Nevada contractor's driller's number issued by the Division of Water Resources \_\_\_\_\_  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1386  
 Signed T. Am By driller performing actual drilling on site or contractor  
 Date Sept. 5, 1987