

OFFICE USE ONLY
 Log No. 29376
 Permit No. _____
 Basin 101-CARSON DESERT

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 9740

1. OWNER Stanley McElhoney ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 1270 Dodgeon Road _____
Ballou, NV. 89406
 2. LOCATION NW 1/4 SW 1/4 Sec. 5 T. 18 N/S R. 29 _____ County _____
 PERMIT NO. none Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay, Brown		0	38	38
Sandy Clay Black		38	58	20
Clay, Black		58	65	7
Sand + Clay Black		65	67 1/2	2 1/2
Sand & gravel, Gray sand		67 1/2	68	1/2
Sand & coarse gravel		68	88	20
Coar strong		88	98	10
Clay, Black		98	98 1/2	1/2
Clay + Brown		98 1/2	107 1/2	10
Sand Brown		107 1/2	108 1/2	1
Gravel, Brown	15	107 1/2	108 1/2	1

8. WELL CONSTRUCTION

Diameter 6 inches Total depth 108 1/2 feet
 _____ inches
 _____ inches
 Casing record + 2 1/2" to 108 1/2'
 Weight per foot 17.02 Thickness .250

Diameter	From	To
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type neat
 Depth of seal 25 feet
 Gravel packed: Yes No
 Gravel packed from 107 1/2' feet to 108 1/2' feet
 Perforations:
 Type perforation Touch
 Size perforation 5/8" x 4"
 From 108 1/2' feet to 108 1/2' feet
 From _____ feet to _____ feet

Date started 12-7- 1987
 Date completed 12-14- 1987

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>3600</u>	<u>10</u>	<u>40</u>	<u>2 hrs</u>
<u>Set Pump @ 90'</u>			
<u>Start Pump over 10:00 PM</u>			

BAILER TEST

G.P.M.	Draw down	feet	hours
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

9. WATER LEVEL
 Static water level 15 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality Excellent

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Water-Rite Well Drilling
 Address P.O. Box 883 Ballou, NV. 89406
 Nevada contractor's license number issued by the State Contractor's Board 0023978
 Nevada contractor's driller's number issued by the Division of Water Resources 1473
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1473
 Signed Sherald J. Olson
 By driller performing actual drilling on site or contractor
 Date 12-14-87