

OFFICE USE ONLY
 Log No. 22386
 Permit No. 7-923
 Basin 7-923

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 9581

1. OWNER STEVEN KYLE ADDRESS AT WELL LOCATION Page 1 of 2 pages
 MAILING ADDRESS 8005 Military Road Same
Reno, NV 89506

2. LOCATION SW 1/4 SW 1/4 Sec. 33 T. 21N N/S R. 19 E Washoe County
 PERMIT NO. 86-421-02 Parcel No. Lemmon Valley Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil		0	1	1
Brown sandy clay with some gravels		1	44	43
Soft zone		44	46	2
Soft weathered granite		46	55	9
Soft zone	X	55	62	7
Weathered granite		62	63	1
Soft zone	X	63	66	3
Weathered granite with clay streeaks		66	74	8
Soft zone	X	74	84	10
Weathered granite		84	89	5
Soft zone		89	92	3
Weathered granite with clay streaks		92	102	10
Soft zone		102	103	1
Weathered granite		103	117	14
Soft zone	X	117	119	2
Weathered granite with clay streaks		119	123	4
Soft zone	X	123	126	3
Weathered granite with clay streaks		126	165	39
Soft zone (No H2O)		165	166	1
Weathered granite		166	173	7
Soft zone (No H2O)		173	178	5

8. WELL CONSTRUCTION
 Diameter 6 inches Total depth 296 feet
 Casing record 296' steel casing instlled
 Weight per foot .156 Thickness
 Diameter From To
6 5/8 inches 0 feet 296 feet
 Surface seal: Yes No Type Cement
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 296 feet
 Perforations:
 #1 Type perforation factory sawed slot/down hole perf
 Size perforation 3/32 x 3 x 6 around
 From 80 feet to 140 feet #2
 From 245 feet to 291 feet #1

Date started 12-9-87, 19.....
 Date completed 12-16-87, 19.....

9. WATER LEVEL
 Static water level 23 feet below land surface
 Flow 24 G.P.M. P.S.I.
 Water temperature cold °F Quality clear

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Wayne Drilling, Inc. Contractor
 Address P.O. Box 12370, Reno, NV 89510 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 22549
 Nevada contractor's driller's number issued by the Division of Water Resources 908
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
 Signed Wayne Drilling, Inc. by driller performing actual drilling on site or contractor
 Date December 19, 1987

BAILER TEST
 G.P.M. Draw down feet hours
 G.P.M. Draw down feet hours
 G.P.M. Draw down feet hours

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 9581

1. OWNER STEVE KYLE ADDRESS AT WELL LOCATION Page 2 of 2 pages
 MAILING ADDRESS XXXXMilitary Road 8005 Same
Reno, NV 89506

2. LOCATION 1/4 Sec. T N/S R. E County
 PERMIT NO. 86-421-02 Lemmon Valley
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Cont. from page 1.				
Weathered granite		178	195	17
Soft zone (No H2O)		195	201	6
Brown clay		201	220	19
Weathered granite with clay streaks		220	273	53
White clay		273	280	7
Weathered granite	X?	280	315	35
Soft zone	X	315	317	2
Weathered granite		317	318	1
Soft zone		318	321	3
Weathered granite		321	335	14
Soft zone		335	341	6
Weathered granite		341	361	20
Soft zone		361	364	3
Weathered granite		364	371	7
Soft zone		371	376	5
Weathered granite		376	403	27

NOTE: From 296 to 403 test hole (cave in)

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
 G.P.M. Draw downfeethours
 G.P.M. Draw downfeethours
 G.P.M. Draw downfeethours

8. WELL CONSTRUCTION

Diameter.....inches Total depth.....feet
inches
inches

Casing record.....
 Weight per foot..... Thickness.....

Diameter	From	To
.....inchesfeetfeet

Surface seal: Yes No Type.....
 Depth of seal.....feet
 Gravel packed: Yes No
 Gravel packed from.....feet to.....feet

Perforations:
 Type perforation.....
 Size perforation.....
 From.....feet to.....feet
 From.....feet to.....feet
 From.....feet to.....feet
 From.....feet to.....feet
 From.....feet to.....feet

9. WATER LEVEL
 Static water level 23 feet below land surface
 Flow 24 G.P.M. P.S.I.
 Water temperature.....°F Quality.....

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Wayne Drilling, Inc.
Contractor
 Address P.O. Box 12370, Reno, NV 89510
Contractor
 Nevada contractor's license number issued by the State Contractor's Board 22549
 Nevada contractor's driller's number issued by the Division of Water Resources 908
 Nevada driller's license number issued by the Division of Water Resources the on-site driller 923
 Signed Wayne Drilling, Inc.
By driller performing actual drilling on site or contractor
 Date December 19, 1987