

WELL DRILLER'S REPORT

NOTICE OF INTENT NO. 6948
 ADDRESS AT WELL LOCATION Southern California Edison Co. Mohave Generating Station

PRINT OR TYPE ONLY

Please complete this form in its entirety

1. OWNER Southern California Edison Co. ADDRESS AT WELL LOCATION Southern California Edison Co. Mohave Generating Station
 MAILING ADDRESS P.O. Box 800 Edison Co. Mohave Generating Station
Rosemead, CA 91770 2700 Edison Road, Laughlin, NV 89029
 2. LOCATION NW 1/4 NW 1/4 Sec. 26 T. 32S. N/S R. 66 Clark County
 PERMIT NO. _____ Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Fly ash & native soil overburden		0	53	53
Yellow to brown clay		53	90	37
Course sand to pea gravel		90	110	20
Sugar sand, fine well graded		110	150	40
Yellow clay & caliche		150	170	20
Med. to course sand		170	210	40
Crs. sand to pebble gravel		210	250	40
Med. to crs. sand		250	310	60
Med. to crs. sand 20% clays		310	351	41

8. WELL CONSTRUCTION
 Diameter 12 1/2 inches Total depth 351 feet
 Casing record 5" PVC screen & blank
 Weight per foot _____ Thickness sch. 80
 Diameter 5" inches From 2' abv. gnd. To 285 feet
 Surface seal: Yes No Type Sand 50% 12sk cem.
 Depth of seal 0-70' yard feet
 Gravel packed: Yes No
 Gravel packed from 290 feet to 230 feet
 Perforations:
 Type perforation slotted PVC
 Size perforation .040
 From 285 feet to 235 feet
 From _____ feet to _____ feet

RECEIVED
 DEC 07 1987
 Div. of Water Resources
 Branch Office - Las Vegas, NV

Date started Oct. 13, 1987
 Date completed Oct. 15, 1987

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	30	32'	24 hrs.

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL
 Static water level 189.8 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature 74 °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name David H. Stewart Contractor
 Address P.O. Box 2067, Grants, N.M. 87021 Contractor
 Nevada contractor's license number 0017868 Class A issued by the State Contractor's Board
 Nevada contractor's driller's number 1447 Sub 6 issued by the Division of Water Resources
 Nevada driller's license number issued by the Division of Water Resources 1447
 Signed David H. Stewart By driller performing actual drilling on site or contract
 Date 12-1-87