WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 29415
Permit No.
Basin 212

1. OWNER BROWN, CHARLIE ADDRESS 7465 BUCKSKIN AVE LAS VEGAS NV. 89129

2. LOCATION NE ¼ SE ¼ Sec. 35 T. 19 N/S R. 62 E. CLARK County
PERMIT NO.

3. TYPE OF WORK: New Well [X] Recondition [ ] Deepen [ ] Other [ ]

4. PROPOSED USE: Domestic [X] Irrigation [ ] Test [ ] Municipal [ ] Industrial [ ] Stock [ ] Other [ ]

5. TYPE WELL: Cable [ ] Rotary [X] Other [ ]

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND & GRAVEL		0'	55'	55'
CLAY		55'	140'	85'
CLAY & GRAVEL	x	140'	145'	5'
CLAY		145'	165'	20'
GRAVEL & CLAY	x	165'	185'	20'
SANDY CLAY		185'	210'	25'
GRAVEL & CLAY	x	210'	220'	10'
SANDY CLAY		220'	230'	10'
GRAVEL & CLAY	x	230'	245'	15'
CLAY		245'	250'	5'
CLAY & GRAVEL		250'	285'	35'
CALICHE		285'	295'	10'
SANDY CLAY		295'	325'	30'
GRAVEL & CLAY	x	325'	350'	25'
CLAY		350'	355'	5'
GRAVEL & SANDY CLAY	xxx	355'	390'	35'
CLAY		390'	398'	8'
FINE SAND		398'	401'	3'

2 FT CEMENT PLUG IN BOTTOM OF WELL AFTER PIPE WAS SET IN PLACE

RECEIVED
NOV 14 1986
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 10-27-86
Date completed 10-31-86

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 12¼ inches Total depth 401 feet
Casing record 8 5/8
Weight per foot ..... Thickness .....

Diameter	From	To
8 5/8 inches	0 feet	401 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes [X] No [ ] Type Cement
Depth of seal 75 FT feet
Gravel packed: Yes [X] No [ ]
Gravel packed from 75 feet to 401 feet

Perforations:
Type perforation FACTORY CUT
Size perforation .....
From 260 feet to 280 feet
From 300 feet to 320 feet
From 340 feet to 360 feet
From 380 feet to 400 feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 114 Feet below land surface
Flow ..... G.P.M.
Water temperature ..... ° F. Quality .....

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WAYNE FLOYD
Address 4375 N. 109A
Nevada contractor's license number 0016696
Nevada driller's license number 643
Signed Wayne L. Floyd
Date 11/5/86

USE ADDITIONAL SHEETS IF NECESSARY

O-627