WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

FINALIZED MH

PRINT OR TYPE ONLY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 29461
Permit No.
Basin 92 B

NOTICE OF INTENT NO. 9586

1. OWNER WILLIAM HARVEY
MAILING ADDRESS 9479 Wigwam Way
Reno, NV 89506

ADDRESS AT WELL LOCATION
11745 Fir DRIVE
Reeno, NV 89506

2. LOCATION SW ¼ NE ¼ Sec. 15 T 21 N N/S R 19 E Washoe County

PERMIT NO. Issued by Water Resources | 80-~~38~~-01 Parcel No. 80-383-01 | Lemmon Valley Subdivision Name 3/10/09

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐ air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	2	2
Brown sandy clay		2	3	1
Soft zone		3	4	1
Brown sandy clay		4	18	12
Soft zone		18	20	2
Brown sandy clay		20	34	14
Soft zone		34	36	2
Brown sandy clay		36	65	29
Weathered granite with some streaks of clay		65	148	83
WeAthered granite		148	170	22
Fracture	X	170	174	4
Weathered granite		174	184	10
Fracture	X	184	193	9
Weathered granite		193	200	7
See deepening Log # 110405				
39.688,571°N NAD27				
119.836,244°W				

'88 FEB -1 A10:33
RECEIVED
STATE ENGINEERS OFFICE

Date started 1-19-88, 19
Date completed 1-19-88, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter 6 5/8 inches Total depth 200 feet
inches
inches
Casing record 200' steel casing installed.
Weight per foot Thickness .156

Diameter	From	To
6 5/8 inches	0 feet	200 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type cement
Depth of seal 51 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 51 feet to 200 feet

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 6 around
From 165 feet to 195 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 124 feet below land surface
Flow 25+ G.P.M. P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling, Inc.
Contractor
Address P.O. box 12370, Reno, NV 89510
Contractor
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada contractor's driller's number issued by the Division of Water Resources 908
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed [signature]
By driller performing actual drilling on site or contractor
Date January 22, 1988

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627