

OFFICE USE ONLY
 Log No. 29505
 Permit No. 51476
 Basin. 6-25
Dec. 01/06/88 9526
 NOTICE OF INTENT NO. 9526

1A South

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

1. OWNER Goldenwest/Sunset Assoc
 MAILING ADDRESS 255 Glendale Ave. Suite 15 Sparks, NV 89431 ADDRESS AT WELL LOCATION Old Spanish Springs Rd
 2. LOCATION SE SW 1/4 Sec 35 T. 21 N/S R. 20 E Washoe County
 PERMIT NO. 51476 W-244 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Compact fill		0	3	3
Brown clay		3	12	9
Brown clay reddish brown yellow & white volcanic sand		12	70	58
Brown clay with tracks of sands		70	110	40
Yellow brown reddish brown green & white volcanic sands & gravels		110	215	105
Volcanic sand with brown clay layers		215	245	30
Green clay with some volcanic sand		245	253	8
Green sticky clay		253	400	147
T.D. 400 feet				

8. WELL CONSTRUCTION
 Diameter 10 inches Total depth 400 feet
 Casing record 6 5/8 inches
 Weight per foot 10.78 Thickness .156
 Diameter From To
6 5/8 inches +2 feet 258 feet
 Surface seal: Yes No Type neat cement
 Depth of seal 96 feet
 Gravel packed: Yes No
 Gravel packed from 96 feet to 400 feet
 Perforations:
 Type perforation factory
 Size perforation 3/32 X 3
 From 110 feet to 250 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Date started 12/14/87 19____
 Date completed 12/17/87 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew with air for 4 hours to clean and develop.			

BAILER TEST

G.P.M.	Draw down	feet	hours

9. WATER LEVEL
 Static water level 20 feet below land surface
 Flow 250 G.P.M. P.S.I.
 Water temperature cold °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Aqua Drilling & Well Service, Inc.
 Address 625 Spice Islands Dr. Suite L Sparks, NV 89431
 Nevada contractor's license number 15291
 issued by the State Contractor's Board
 Nevada contractor's driller's number 1132
 issued by the Division of Water Resources
 Nevada driller's license number issued by the 1511
 Division of Water Resources, the on-site driller
 Signed Roger M. Thrall
 By driller performing actual drilling on site or contractor
 Date 12/28/87