

OFFICE USE ONLY
Log No. 29600
Permit No. _____
Basin 7-92a

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 9579

1. OWNER JAMES STOCKMAN ADDRESS AT WELL LOCATION _____
MAILING ADDRESS 1730 Riley 10215 Blackhawk
Reno, Nv 89502 Reno, NV 89506
2. LOCATION NE 1/4 NE 1/4 Sec 24 T 21N N/S R 18 E Washoe County
PERMIT NO. 86-232-06 Silver Knolls
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/> Deepen <input type="checkbox"/> Other <input type="checkbox"/>	4. PROPOSED USE Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Test <input type="checkbox"/> Stock <input type="checkbox"/>	5. TYPE WELL Cable <input type="checkbox"/> Rotary <input checked="" type="checkbox"/> Other <input type="checkbox"/> Air
--	---	---

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil		0	1/2	1/2
Brown sandy clay		1/2	105	104 1/2
Soft zone brown sand		105	111	6
Brown soft sandy clay		111	126	15
Soft zone	X	126	130	4
Brown clay		130	135	5
Soft zone	X	135	141	6
Brown clay		141	156	15
Soft zone	X	156	171	15
Brown sandy clay		171	175	4

8. WELL CONSTRUCTION

Diameter 6 inches Total depth 175 feet
Casing record 175' steel casing installed
Weight per foot _____ Thickness .156
Diameter From To
6 5/8 inches 0 feet 175 feet
Surface seal: Yes No Type cement
Depth of seal 50 feet
Gravel packed: Yes No
Gravel packed from 50 feet to 175 feet
Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 6 around
From 130 feet to 170 feet

Date started 2-4-88, 19____
Date completed 2-5-88, 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. _____ Draw down _____ feet _____ hours
G.P.M. _____ Draw down _____ feet _____ hours
G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL

Static water level 95 feet below land surface
Flow 20 G.P.M. _____ P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling, Inc. Contractor
Address P.O. Box 12370, Reno, NV 89510 Contractor
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada contractor's driller's number issued by the Division of Water Resources 908
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed [Signature] By driller performing actual drilling on site or contractor
Date February 9, 1988