WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 296665
Permit No.
Basin
In Book

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 4452

1. OWNER HERBERT FENDREY
MAILING ADDRESS P.O. BOX 2915
PAHRUMP, NEV. 89041
ADDRESS AT WELL LOCATION

2. LOCATION N.W. ¼ N.W. ¼ Sec. 28 T. 20 N/S R. 53 E NYE County
PERMIT NO. (Issued by Water Resources) | LOT 35 BLK 14 (Parcel No.) | UNIT 8B CALVADA VALLEY (Subdivision Name)

3. TYPE OF WORK
New Well [X] Recondition [ ]
Deepen [ ] Other [ ]

4. PROPOSED USE
Domestic [X] Irrigation [ ] Test [ ]
Municipal [ ] Industrial [ ] Stock [ ]

5. TYPE WELL
Cable [X] Rotary [ ]
Other [ ]

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	1	1
HARD BROWN CLAY		1	5	4
HARD WHITE CALECHE		5	9	4
BROWN CALECHE		9	32	23
HARD BROWN CALECHE		32	36	4
BROWN CALECHE		36	67	31
HARD BROWN CLAY		67	73	6
BENTONITE CLAY		73	84	11
BROWN CLAY		84	89	5
HARD BROWN CALECHE		89	104	25
BROWN CALECHE		104	121	17
HARD BROWN CALECHE		121	124	3
GREEN CLAY		124	140	16

RECEIVED
MAR 29 1988
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 2-4, 1988
Date completed 2-8, 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 12 inches Total depth 140 feet
Casing record 140 FT. 8 5/8" O.D. STEEL
Weight per foot 14.11 Thickness .156

Diameter	From	To
8 5/8 inches	0 feet	140 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes [X] No [ ] Type
Depth of seal 50 feet
Gravel packed: Yes [ ] No [X]
Gravel packed from ..... feet to ..... feet

Perforations:
Type perforation TORCH CUT
Size perforation 3/8" X 8"
From 70 feet to 140 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 31 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature ..... ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name ROD FLOYD PUMP + DRILLING (Contractor)
Address BOX 157 PAHRUMP, NEV. 89041 (Contractor)
Nevada contractor's license number ~~1424~~ 7479-A
Nevada contractor's drillers number 1424
Nevada driller's license number 1427 - STAN HARDY (Actual Driller)
Signed (Contractor)
Date 2-15-88

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434