

**WELL DRILLERS REPORT**

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 10055

1. OWNER D. Lafayette ADDRESS AT WELL LOCATION 974 Copperwood  
 MAILING ADDRESS 425 So. Laverne

2. LOCATION SE 1/4 SE 1/4 Sec. 29 T. 19 N/S R. 28 E. Churchill County  
 PERMIT NO. \_\_\_\_\_ Parcel No. Copperwood Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other  Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	4	4
Silty Sand		4	12	12
Silt	X	12	16	4
Clay		16	24	8
Silt	X	24	34	10
Block Sand	X	34	63	29
Sand & Gravel	X	63	87	24

8. WELL CONSTRUCTION

Diameter hole 6 1/2 inches Total depth 87 feet  
 Casing record 6 1/2" x 87  
 Weight per foot 12.92 Thickness .188

Diameter	From	To
<u>6</u> inches	<u>0</u> feet	<u>50</u> feet
<u>6</u> inches	<u>50</u> feet	<u>85</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes  No  Type \_\_\_\_\_  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from \_\_\_\_\_ feet to \_\_\_\_\_ feet

Perforations:  
 Type perforation Machine Slot  
 Size perforation 1/8" x 2 1/2"  
 From 79 feet to 85 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL

Static water level 7 feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature 62 ° F. Quality \_\_\_\_\_

Date started 3-2, 1988  
 Date completed 3-2, 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>Air Blown @ 75</u>			

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Welsco Drilling Contractor  
 Address Box 888 Contractor  
 Nevada contractor's license number 11752  
 Nevada contractor's drillers number 772  
 Nevada driller's license number 772 Actual Driller

Signed W. Apple Contractor  
 Date 3-3-88

BAILER TEST

G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours