


Log No. 29791
 Permit No. _____
 Basin 222



WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. _____

1. OWNER Bruce Jensen ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS Post Office Box 9
Mesquite, Nevada 89024

2. LOCATION NW 1/4 SE 1/4 Sec 30 T 13 S 71 E Clark County
 PERMIT NO. _____ Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Gravel		0	25	25
Sand		25	30	5
Gravel		30	35	5
Red sand		35	40	5
Gravel		40	55	15
Gravel some clay		55	60	5
Sand		60	70	10
Gravel, red clay, sand		70	90	20
Gravel & sand		90	100	10
Red clay, sand, some gravel		100	115	15
Red clay		115	130	15
Red clay & gravel		130	135	5
Red clay, sand, some gravel		135	145	10
Sandy gravel		145	170	25
Gravel & clay mixed		170	215	45
Sandy gravel		215	250	35
Gravel		250	300	50
Red sandy clay		300	320	20

8. WELL CONSTRUCTION
 Diameter 9 7/8 inches Total depth 320 feet
 _____ inches
 _____ inches

Casing record _____
 Weight per foot _____ Thickness .188

Diameter	From	To
<u>6</u> inches	<u>+1</u> feet	<u>303</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type Cement
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 320 feet

Perforations:
 Type perforation _____
 Size perforation _____
 From 245 feet to 285 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

RECEIVED
APR 15 1988
 Div. of Water Resources
 Branch Office - Las Vegas, NV

Date started February 22, 1988
 Date completed March 3, 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL
 Static water level 153 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name THOMPSON DRILLING CO., INC.
4185 West Harmon
 Address Las Vegas, Nevada 89103
 Contractor

Nevada contractor's license number issued by the State Contractor's Board 4286A

Nevada contractor's driller's number issued by the Division of Water Resources 290

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1489

Signed Richard K. Thompson
 By driller performing actual drilling on site or contractor

Date April 13, 1988

