WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 29823
Permit No.
Basin

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 4455

1. OWNER TOM WOOD
MAILING ADDRESS GEN. DEL.
PAHRUMP, NEV. 89041

ADDRESS AT WELL LOCATION
PLUTO WEST OF VICKIE ANN
PAHRUMP, NEV.

2. LOCATION S.E. ¼ N.E. ¼ Sec. 2 T. 21 M/S R. 53 E NYE County
PERMIT NO. (Issued by Water Resources) LOT 27 BLK E (Parcel No.) GAMEBIRD (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	1	1
WHITE CALICHE		1	4	3
BROWN CALICHE		3	12	9
HARD BROWN CALICHE		12	16	4
WHITE CALICHE		16	24	8
BROWN CALICHE		24	33	9
HARD BROWN CALICHE		33	50	17
BROWN CALICHE		50	61	11
HARD BROWN CALICHE		61	64	3
BROWN CALICHE		64	69	5
HARD BROWN CALICHE		69	75	6
BROWN CALICHE		75	83	8
HARD BROWN CALICHE		83	86	3
BROWN CALICHE		86	99	13
HARD BROWN CALICHE		99	115	16
BROWN CLAY		115	126	11
HARD BROWN CALICHE		126	140	14
W/ LAYERS BROWN CLAY				

RECEIVED
APR 8 1988
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 3-15, 1988
Date completed 3-21, 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 12 inches Total depth 140 feet
Casing record 140 FT. 8 5/8" O.D. STEEL
Weight per foot 17.4 Thickness .188

Diameter	From	To
8 5/8 inches	0 feet	140 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type CEMENT
Depth of seal 50 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from ..... feet to ..... feet

Perforations:
Type perforation TORCH CUT
Size perforation 3/8" X 8"
From 70 feet to 140 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 35 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature ..... ° F. Quality .....

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name ROD FLOYD PUMP & DRILLING (Contractor)
Address P.O. BOX 157 PAHRUMP, NEV. 89041 (Contractor)
Nevada contractor's license number 7479-A
Nevada contractor's drillers number 1424
Nevada driller's license number 1427 - STAN HARDIN (Actual Driller)
Signed ..... (Contractor)
Date 3-23-88

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) 0-627 CR434