WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 28859
Permit No.
Basin G-87

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 9545

1. OWNER James Cathey
MAILING ADDRESS 5017 Pleasant View
Sparks, Nv 89431

ADDRESS AT WELL LOCATION
5022 Pleasant View

2. LOCATION ¼ ¼ Sec. 1 T. 19 N/S R. 20 E Washoe County
PERMIT NO. (Issued by Water Resources) 30-202-04 (Parcel No.) — Lot 10 Sunset View Rancho Estates Unit #2 (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic XX Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary XX
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Reddish brown volcanic cobbles		0	8	8
Reddish brown clay with some volcanic rock		8	17	9
Reddish brown green yellow volcanic rock		17	29	12
Fractured & broken volcanic rock		29	280	251
Reddish brown green black & white volcanic sands & gravel		280	325	45
Blue clay with some volcanic sands		325	398	73
Dark green fractured rock		398	465	67
T.D. 465				

Date started 3/9/88, 19
Date completed 4/21/88, 19

8. 11"- 65' WELL CONSTRUCTION
Diameter 7 7/8 inches Total depth 465 feet
6 1/4 inches
inches
Casing record 6 5/8" & 5"
Weight per foot 10.78 & 6.96 Thickness .156 & .134

Diameter	From	To
6 5/8 inches	+1 1/3 feet	280 feet
5 inches	265 feet	465 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type grout
Depth of seal 56 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 56 feet to 280 feet

Perforations:
Type perforation factory
Size perforation 3/32 X 3
From 260 feet to 280 feet
From 405 feet to 445 feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 206 feet below land surface
Flow 20+ G.P.M. P.S.I.
Water temperature cold °F Quality

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew with air to clean and develop.			

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Aqua Drilling & Well Service, Inc. (Contractor)
Address 625 Spice Islands Dr. Suite L Sparks, Nv 89431 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 15291
Nevada contractor's driller's number issued by the Division of Water Resources 1132
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1511
Signed Roger M. Thrall (By driller performing actual drilling on site or contractor)
Date Roger M. Thrall 4/28/88

RECEIVED STATE ENGINEER'S OFFICE 88 MAY -3 AM 10:35

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627