

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 4541

PRINT OR TYPE ONLY

1. OWNER LANE HOLDAMAN ADDRESS AT WELL LOCATION 753 BUCKSKIN
 MAILING ADDRESS Box 607
GARDNERVILLE, NV.

2. LOCATION NW 1/4 NW 1/4 Sec. 19 T. 12 S. R. 21 E. DOUGLAS County
 PERMIT NO. 29-470-17 Parcel No. RHUESTRA Subdivision Name

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/>	Cable <input checked="" type="checkbox"/> Rotary <input type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>	Other <input type="checkbox"/>

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY		0	4	
CLAY GRAVEL		4	11	
CLAY SAND		11	127	
CLAY		127	170	
GRAVEL	XX	170	190	
SAND	XX	190	196	
CLAY		196	228	
GRAVEL	XX	228	245	

8. WELL CONSTRUCTION

Diameter 12" inches Total depth 245 feet
8 5/8" inches
 inches

Casing record 245'

Weight per foot _____ Thickness 250

Diameter	From	To
<u>12</u> inches	<u>0</u> feet	<u>60</u> feet
<u>8 5/8</u> inches	<u>60</u> feet	<u>245</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type Cement
 Depth of seal 60 feet
 Gravel packed: Yes No
 Gravel packed from _____ feet to _____ feet

Perforations:
 Type perforation Factory slot
 Size perforation 3x3/32
 From 180 feet to 240 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

RECEIVED
 APR 25 1988

STATE ENGINEER'S OFFICE

Date started 3-30-88, 19____
 Date completed 4-20-88, 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. 18 Draw down 3 feet 2 hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL

Static water level 146 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name KAWCHACK DRILLING INC. Contractor
 Address Box 536 Gardnerville, Nev. Contractor

Nevada contractor's license number issued by the State Contractor's Board 021268
 Nevada contractor's driller's number issued by the Division of Water Resources 1380
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 763

Signed Song Kawchack
 By _____ driller performing actual drilling on site or contractor
 Date 4-21-88