WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 29897
Permit No. 51810
Basin 4-48

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 10037

1. OWNER Newmont Gold Company
MAILING ADDRESS P.O. Box 669
Carlin, NV 89822

ADDRESS AT WELL LOCATION
Dixie Flats Obervation Well #3

2. LOCATION SE ¼ NE ¼ Sec. 9 T. 31 N/S R. 54 E. Elko County
PERMIT NO. W-253/51810 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☒ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Rock & gravel clay		0	20	20
Clay		20	40	20
gravel & sand little clay		40	80	40
clay & sand		80	100	20
clay, gravel & sand		100	120	20
clay & gravel		120	160	40
clay, gravel, sand		160	180	20
sandy clay & clay		180	200	20
60% sand 40% clay		200	220	20
50% grav 30 sand 20 clay		220	240	20
50% clay 50% sand		240	260	20
70%sand 30% clay		260	300	40
60% clay 40% sand		300	440	140
sand, gravel, clay		440	480	40
clay & sand		480	500	20
clay		500	520	20
clay & sand		520	540	20
sand & gravel		540	560	20
clay & sand		560	600	40
clay & gravel		600	620	20
clay & sand clay		620	640	20
clay & fine gravel		640	660	20
clay sand & gravel		660	680	20
- -		680	700	20

Date started 3/21/, 19 88
Date completed 3/30/, 19 88

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 12 inches Total depth 700 feet
..... inches
..... inches
Casing record 6 5/8" O.D. x 1/4" wall
Weight per foot ..... Thickness .....

Diameter	From	To
12 inches	±2 feet	700 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type cement grout
Depth of seal 80' feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 80' feet to 700 feet
Chevreaux quartz pebbles
Perforations:
Type perforation Mill Slot
Size perforation .....
From 40 feet to 440 feet
From 540 feet to 700 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 46.8 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature ..... °F Quality .....

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name SARGENT IRRIGATION COMPANY (Contractor)
Address P.O. Box 2646 Elko, NV (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 21246
Nevada contractor's driller's number issued by the Division of Water Resources 1391
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1541 * 1542
Signed [signature] (By driller performing actual drilling on site or contractor)
Date April 18, 1988

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627