WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 29908
Permit No.
Basin 7-93

PRINT OR TYPE ONLY 23 AVP

NOTICE OF INTENT NO. 10140

1. OWNER JOHN & TERI OBERHOLTZER
MAILING ADDRESS P.O. Box 2730
Sparks, NV 89432

ADDRESS AT WELL LOCATION
1427 Oberholtzer Crt.
Reno, NV 89506

2. LOCATION SE ¼ NE ¼ Sec. 23 T. 22N N/S R. 19 E. Washoe County
PERMIT NO. (Issued by Water Resources) 979-470-208 (Parcel No.) Antelope Valley Red Rock Est. #2654 (Subdivision Name) part 41

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐ Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown clay		0	8	8
Brown sandy clay		8	35	27
Soft zone		35	41	6
Brown sandy clay		41	60	19
Weathered green granite		60	123	63
Weathered granite w/ clay streaks		123	131	8
Weathered green granite		131	206	75
Soft zone (app 1 GPM)	X	206	221	15
Weathered green granite		221	235	14
Soft zone	X	235	267	22
Black granite		267	275	8

'88 MAY -6 A10:26
RECEIVED
STATE ENGINEER'S OFFICE

Date started 4-18-88, 19
Date completed 4-21-88, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter 6 inches Total depth 275 feet
inches
inches
Casing record 275 ft. steel casing installed
Weight per foot Thickness .156

Diameter	From	To
6 5/8 inches	0 feet	275 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type cement
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 275 feet

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 6 around
From 230 feet to 270 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 93 feet below land surface
Flow 15 G.P.M. P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling, Inc. (Contractor)
Address P.O. Box 12370, Reno, NV 89510 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada contractor's driller's number issued by the Division of Water Resources 908
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed [signature] (By driller performing actual drilling on site or contractor)
Date April 25, 1988

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627