WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 29911
Permit No. 19113
Basin 9-108

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 9941

1. OWNER R.N. Fulstone Company
MAILING ADDRESS P.O. Box 61
Smith Valley, NV 89430
ADDRESS AT WELL LOCATION Yerington
2. LOCATION NW ¼ SE ¼ Sec. 2 T. 12 N/S R. 25 E LYON County
PERMIT NO. (Issued by Water Resources) Parcel No. Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other Redrill ☒

4. PROPOSED USE
Domestic ☐ Irrigation ☒ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	4	4
Gravel		4	12	8
Cobbles w/s clay		12	104	92
Sand & Gravel w/good quartz sand		104	130	26
Sand & Gravel in clay		130	135	5
Sand & Gravel		135	144	9
Brown Clay, dry		141	150	9
Sand, gravel & rocks in clay		150	159	9
Fine Sand		159	165	6
Sand & some gravel		165	172	7
Coarse gravel & sand		172	175	3
Coarse sand & gravel w/s clay		175	301	126
Clay w/s sand		301	322	21
Coarse sand & Gravel		322	330	8
Clay		330	338	8
Coarse Sand		338	350	12
Coarse sand w/s clay		350	358	8
Coarse Sand		358	365	7
clay w/sand & gravel stringers		365	390	25
Sand		390	405	15
Sand w/s Clay		405	410	5
Brown Clay		410	415	5
Gravel & clay stringers		415	418	3
Brown Clay		418	430	12

Date started 3/1, 1988
Date completed 3/6, 1988

APR 29 AM 8:38 RECEIVED STATE ENGINEERS OFFICE

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	280	109'	12 hrs

*NOTE This report reflects reaming of well under log #5803

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 24 inches Total depth 430 feet
..... inches
..... inches
Casing record 16"
Weight per foot ..... Thickness ¼"

Diameter	From	To
16" Blank inches	+3 feet	91 feet
16" Slotted inches	91 feet	150 feet
16" FF inches	150 feet	205 feet
16" Perf inches	205 feet	255 feet
16" FF inches	255 feet	280 feet
16" Perf inches	280 feet	380 feet

Surface seal: Yes ☒ No ☐ Type Concrete
Depth of seal 50' feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 430 feet

Perforations:
Type perforation ROSCOE MOSS SHUTTER SCREEN
Size perforation 1/8
From 16" FF 380 feet to 405 feet
From 16" Perf 405 feet to 430 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 20 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature ..... °F Quality .....

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Humboldt Drilling & Pump Co., Inc. (Contractor)
Address P.O. Box 592 Winnemucca, NV 89445 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 015234
Nevada contractor's driller's number issued by the Division of Water Resources C-23
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1448
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 4/28/88

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627