

OFFICE USE ONLY  
Log No. \_\_\_\_\_  
Permit No. \_\_\_\_\_  
Basin 6-91  
NOTICE OF INTENT NO. 9500



**WELL DRILLER'S REPORT**

Please complete this form in its entirety

PRINT OR TYPE ONLY

1. OWNER Chris Glover ADDRESS AT WELL LOCATION  
MAILING ADDRESS 1701 Greg 300 Sylvan Cr  
Sparks, Nv 89431 Verdi

2. LOCATION 1/4 SE 1/4 Sec 7 T 19 N/S R 18 E Washoe County  
PERMIT NO. 38-046-19 Sunrise Creek Unit # 1 Lot 5 Block B  
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK  
New Well  Recondition   
Deepen  Other

4. PROPOSED USE  
Domestic  Irrigation  Test   
Municipal  Industrial  Stock

5. TYPE WELL  
Cable  Rotary   
Other  AIR

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Pulled 5 9/16 liner out - top damaged at 83'				
Pulled 40' out - bottom of liner is torn apart. There has been a drill bit at this depth drilling. Can not get the remaining liner out. Drill with 6 1/8" bit to 139' - metal at 123' - install 5" liner from 63' - 123'				
T.D. 123				
This well was drilled by Sierra Pump & Drilling in 1983 and never used				
The 5 9/16" liner was torch cut for perfs				

8. WELL CONSTRUCTION  
Diameter 6 1/8 inches Total depth 123 feet  
Casing record 5"  
Weight per foot 6.96 Thickness .134

Diameter	From	To
<u>5</u> inches	<u>63</u> feet	<u>123</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes  No  Type \_\_\_\_\_  
Depth of seal \_\_\_\_\_ feet  
Gravel packed: Yes  No   
Gravel packed from \_\_\_\_\_ feet to \_\_\_\_\_ feet

Perforations:  
Type perforation factory  
Size perforation 3/32 X 3  
From 103 feet to 123 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 5/3/88, 19\_\_\_\_  
Date completed 5/3/88, 19\_\_\_\_

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew with air to clean and develop.			

G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

9. WATER LEVEL  
Static water level 60 feet below land surface  
Flow 12 G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature cold °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Aqua Drilling & Well Service, Inc.  
Address 625 Spice Islands Dr Suite L Sparks, Nv  
Nevada contractor's license number issued by the State Contractor's Board 15291  
Nevada contractor's driller's number issued by the Division of Water Resources 1132  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1511  
Signed Roger M. Thrall  
Date Roger M. Thrall  
By driller performing actual drilling on site or contractor