

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 9549

PRINT OR TYPE ONLY

1. OWNER Don Sprinkle ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 2601 Fair Cr 1635 Monte Vista
Reno, Nv 89503 Lot 7 Block C

2. LOCATION SW 1/4 SE 1/4 Sec 7 T 18 N/S R 20 E Washoe County _____
 PERMIT NO. 44-362-07 - Sierra Manor Subdivision Name _____
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/>	Cable <input type="checkbox"/> Rotary <input checked="" type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>	Other <input type="checkbox"/> Mud <input type="checkbox"/>

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
D.G. cobbles & boulders		0	8	8
Reddish brown green white & yellow coarse sands & gravels with some boulders		8	110	102
Fine sands white yellow browns green		110	180	70
T.D. 180 feet				
Gravel inside casing		163	180	17

8. WELL CONSTRUCTION

Diameter 10 inches Total depth 180 feet

Casing record 6 5/8 inch

Weight per foot 10.78 & 12.92 Thickness .156 & .188

Diameter	From	To
<u>6 5/8</u> inches	<u>+1 1/2</u> feet	<u>180</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type neat cement

Depth of seal 53 feet

Gravel packed: Yes No

Gravel packed from 53 feet to 180 feet

Perforations:

Type perforation factory

Size perforation 3/32 X 3

From 140 feet to 160 feet

From _____ feet to _____ feet

9. WATER LEVEL

Static water level 50 feet below land surface

Flow 20+ G.P.M. _____ P.S.I.

Water temperature cold °F Quality _____

Date started 5/4/88, 19____

Date completed 5/4/88, 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew with air to clean and develop.			

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Aqua Drilling & Well Service, Inc.

Address 625 Spice Islands Dr. Suite L Sparks, Nv 89431

Nevada contractor's license number issued by the State Contractor's Board 15291

Nevada contractor's driller's number issued by the Division of Water Resources 1132

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1511

Signed Roger M. Thrall
 By driller performing actual drilling on site or contractor

Date 5/10/88

BAILER TEST

G.P.M.	Draw down	feet	hours