WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No 29956
Permit No.
Basin 8-101

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 8976

1. OWNER Ken Garcia
MAILING ADDRESS P.O. Box 2068 Fallon, NV. 89406

ADDRESS AT WELL LOCATION 4656 Benson Dr. Fallon, Nv. 89406

2. LOCATION SW ¼ NE ¼ Sec. 2 T. 18 N/S R. 29 E. Churchill County
PERMIT NO. None (Issued by Water Resources) #15 (Parcel No.) W.E. Turman Subdivision (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay, Brown		0	45	45
Clay, Black		45	75	30
Clay, Green		75	81	6
Sand Fine, Green		81	89	8
Clay, Gray		89	98	9
Sand med Course Brown	16'-4"	98	106	8
Sand & pea gravel	6'-8"	106	108	2
Clay, brown		108		

Date started 5-4, 1988
Date completed 5-6, 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
3600	15	10'	1/2
Set pump at 60 ft. Dont pump over 15 g.p.m.			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 6 inches Total depth 108'-9" feet
..... inches
..... inches
Casing record Steel
Weight per foot 17.02 Thickness .250

Diameter	From	To
6 inches	+20" feet	108'-9" feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type neat
Depth of seal 50 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from ..... feet to ..... feet

Perforations:
Type perforation Torch
Size perforation 5/32 x 4"
From 105'-9" feet to 108'-9" feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 6'-8" feet below land surface
Flow — G.P.M. — P.S.I.
Water temperature Cool °F Quality Excellent

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Water-Rite Well Drilling (Contractor)
Address P.O. Box 883 Fallon, Nv. 89406 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0023878
Nevada contractor's driller's number issued by the Division of Water Resources 1473
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1473
Signed Gerald W. Olson (By driller performing actual drilling on site or contractor)
Date 5-6-88

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627